

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI- 110001**

NO.F6/DFS/MS/School/2018/SZ/ 590

Dated: 5/4/18

**FIRE SAFETY CERTIFICATE**

Certified that the Shiksha Gyan Vidhalaya, A-7, Nishant Park, Kakrola More, New Delhi-110078, comprised of ground floor only was Issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2013/395 dated 30.5.2013. The said school building was re-inspected by the officer concerned of this department on 22.3.2018 in presence of Sh. Virender Gahlot( Manager) and found that the Premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular dated 1.3.2011, and that the building is fit for occupancy class B "Educational building" with effect from 5/4/18..... for a period of **three years**, subject to compliance of the conditions, printed overleaf.

Issued on 5/4/18..... at New Delhi by

*W*  
*4/4*  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
*5/4*

Copy to:-

1. Director (Education), Govt. of NCT of Delhi, old Secretariat, Delhi-110054.
2. Manager, Shiksha Gyan Vidhalaya, A-7, Nishant Park, Kakrola More, New Delhi-110078.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	Shiksha Gyan Vidhalaya, A-7, Nishant Park, Kakrola More, New Delhi-110078.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal	Ground Floor only	
4	Details of previous NOC	No.F6/DFS/MS/School/2013/395 dated 30.5.2013		
5	Fire safety directives letter No	Edu. Circular. No. 3298-3398 dated 1.3.2011		
6	Date of inspection	22.3.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Virender Gahlot (Manager)		
9	Year of construction	2006		
10	Applicant's letter No.	SGV/01/2017-2018 dated 27.2.2018	(Ground Floor only)	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>DOE CIR. 17.1.2005/ letter dated 5.12.2013</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtr.	90x195 Cms.	MR being old case
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	3 Nos.	3 Nos.	MR
	Types		CO2 & ABC	MR
	ISI marking		Provided	

6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N19

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric meter	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required as DOE CIR. 1.3.2011, renewal of FSC issued vide letter no.F6/DFS/MS/School/2013/395 dated 30.5.2013 is recommended.

Accordingly DFA is put up for approval and signature please.

*Sew*  
28/3/18

S.P. Bhardwaj  
ADO (Dwarka)

258/DO(SW)

dt. 26/03/18

*DO(SW)*

*dt*  
26/3/18

*DCFO(S2)*

*Kamp*  
26/3



*FT/10*  
*CFD SPM m.scell*  
28/3

FT is put up for signature please

1164/CF/S2  
2/4

*Chrsy*  
m.scell  
2/4

*Sew*  
24/1/18