

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2018/SZ/ 588

Dated: 5/4/18

FIRE SAFETY CERTIFICATE

Certified that the Sir Chhotu Ram Public School located at WZ-727-A, Sir Chhotu Ram Marg, Palam Village, New Delhi-110045, the School building having two blocks, both are interconnected & comprised of ground plus one upper floor was issued Fire Safety Certificate by this department vide letter No.F6/ DFS/MS/School/2013/362 dated 24.5.2013. The said school building was re-inspected by the officer concerned of this department on 16.3.2018 in the presence of Smt. Kanta Solanki (Manager) and found that the premises have deemed with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Circular No. 3298-3399 dated 1.3.2011 and that the building/premises is fit for occupancy of class B "Educational Building" with effect from 5/4/18 for a period of **three years** subject to compliance of the conditions , printed overleaf.

Issued on 5/4/18 at New Delhi by

VK
4/4
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

- 1 Dy. Director (Education) GNCT of Delhi, Old Secretariat, Delhi-110054.
- 2 Principal, Sir Chhotu Ram Public School located at WZ-727-A, Sir Chhotu Ram Marg, Palam Village, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sir Chhotu Ram Public School, WZ-727-A, Sir Chhotu Ram Marg, Palam Village, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal G+1		
4	Details of previous NOC	No.F6/MS/DFS/School/2013/362 dated 24.5.2013		
5	Fire safety directives letter No	D.O.Edu. Circular. No.3298-3398 dated 1.3.2011.		
6	Date of inspection	16.3.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Kanta Solanki (Manager)		
9	Year of construction	2003-4		
10	Applicant's letter No.	117/SCRPS/2017-18 Dated 2.2.2018	(Ground plus one upper floor)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. 1.3.2011/ letter dated 24.5.2013	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtr.	1.50 & 1.40 Mtr.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	1.50 Mtr.	1.55 to 1.75 Mtr.	N/A
	f. Door size	1 Mtr.	85x190 Cms.	MR being old case
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	7 Nos.	7 Nos.	MR
	Types		CO2 & ABC	MR
	ISI marking		Provided	MR

112

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

21

N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric meter.	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety required as DOE CIR. dated 1.3.2011, renewal of FSC is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
19/3/18

S.P. Bhardwaj
ADO (Dwarka)

D/SW

222/DO/SW
19/03/18

dg
19/3/2018

DGFO (\$2)

kanf
21/3 FT/106

CFO (\$2) m.scell *28/3*

FT is put up for signature plan

S.P. Bhardwaj
21/4/18



1161/CFO/52
4/4.

efdsyf m.scell *4/4.*