

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110 001.

No. F.6/DFS/MS/BNQT/2018/SZ/ 703

Dated: 13/4/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Aashirwad Caterers (P) Ltd., A-1/25, Ground floor, Janak Puri, New Delhi-110058 comprised of basement, ground floor plus two upper floors but Banquet hall is running at ground floor only, using basement as storage, ground floor as banquet hall & first floor as personal use, second floor is used for residence purpose owned/occupied by M/s Aashirwad Caterers (P) Ltd. The banquet hall building was inspected by the officers concerned of this department on 28.03.2018 in the presence of Sh. Rajesh Seth (Owner) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises (**Ground floor Only**) is fit for occupancy class Group D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....13/4/18.....at New Delhi.

UK 13/4.
(VIPIN KENTAL)
CHIEF FIRE OFFICER

27c 500
12/4/18

Copy to:-

1. The Deputy Health Officer,
West Zone (SDMC), Public Health Department,
Vishal Enclave, Rajouri Garden, New Delhi.
2. The Owner,
M/s Aashirwad Caterers (P) Ltd. A-1/25, Ground floor,
Janak Puri, New Delhi-110058.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

2/13

Banquet hall building is comprised of basement, ground plus two upper floors but Banquet hall is running at ground floor only and the owner applied for ground floor only

INSPECTION REPORT

1. Name & address of the building : M/s Aashirwad Caterers (P) Ltd. A-1/25, Ground floor, Janak Puri, New Delhi-110058
2. Type of Occupancy : Group 'D' Assembly Building.
3. Type of Case : New
4. Details of Previous NOC : N/A
5. Fire Safety directives letter No : F.6./DFS/MS/2009/1997 dated 07.07.09
(For basement ground plus one upper floor)
6. Date of inspection : 28.03.2018
7. Name of Inspecting Officer : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Rajesh Seth (Owner)
9. Year of Construction : Before 2010
10. Applicant's letter No. : Nil dated 05.01.2018

Comprised of basement, ground plus two upper floors. Using basement (Storage), Ground floor (Banquet Hall), First Floor (Personal Use) & Second Floor (Residence).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5 mtrs NA	20 mtrs. Directly accessible from road NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	For Banquet hall at ground floor only			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
		Required	Provided	M/R
	e. Width of Corridor			
		Required	Opening in hall	M/R
	f. Door Size			
		200 cms (02 no.'s)	Provided	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	Provided	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15 No's W/CO ₂ /CO ₂ type ISI marked	Provided	M/R
			Provided	M/R
			ISI marked	M/R
6.	First-Aid Hose Reels			
	For Banquet hall at ground floor only			

3. Type of Case : New
 4. Details of Previous NOC : N/A
 5. Fire Safety directives letter No : F.6./DFS/MS/2009/1997 dated 07.07.09
 (For basement ground plus one upper floor)
 6. Date of inspection : 28.03.2018
 7. Name of Inspecting Officer : D.O. M.K. Chattopadhyay & A.D.O. Sandeep Duggal
 8. Name and designation of officers
 From the building side : Sh. Rajesh Seth (Owner)
 9. Year of Construction : Before 2010
 10. Applicant's letter No. : Nil dated 05.01.2018
 Comprised of basement, ground plus two upper floors. Using basement (Storage), Ground floor (Banquet Hall), First Floor (Personal Use) & Second Floor (Residence).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 4.5 mtrs NA	20 mtrs. Directly accessible from road NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	For Banquet hall at ground floor only			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	Required	Opening in hall	M/R
	f. Door Size	200 cms (02 no.'s)	Provided	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	N/A	Provided	N/A
	<ul style="list-style-type: none"> Upper floors 	Required	Natural ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	15 No's W/CO ₂ /CO ₂ type ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	For Banquet hall at ground floor only			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 mtrs. 5 mm	Provided Provided Provided	M/R M/R M/R

7. Automatic fire detection and alarming system		For Banquet hall at ground floor only		
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	Provided	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants	For Banquet hall at ground floor only		
	• Size of riser/down-comer	Required	Provided	M/R
	• Number of hydrants per floor	One	Provided	M/R
	• Hose Box	One	Provided	M/R
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements	For Banquet hall at ground floor only		
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M/R
	➤ Head of the pump	30 mtrs.	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14.	Captive Water Storage for fire fighting	For Banquet hall at ground floor only		
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	Provided	N/A
	• Lift Signage	N/A	Provided	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

7/15

Banquet hall building is comprised of basement, ground plus two upper floors but Banquet hall is running at ground floor only and the owner applied for ground floor only

19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter no. F.6/DFS/MS/BNQT/2016/504 dated 24.02.2016 has been complied.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- As per the letter submitted by Sr. Manager Admin Dept. (placed at C-45) the basement is segregated with gypsum board from both sides and the lift has also been blocked and segregated by installing gypsum board in front of the lift at basement.

[Signature]
02/4/2018

Signature of Inspecting Officer
Name:- M.K. Chattopadhyay
Designation:- Divisional Officer

Sandeep
02/4/18

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

79/DO/SW
3/4/18

Dy. C.F.O (South Zone)

[Signature]
4/4

CFO (S/Z) M.Scell Ue 6/4.

F.T. letter is put up for signature pl.

Sandeep
12/4/18

[Signature] M.Scell Ue 13/4

