

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2018/ EH/w2/706

Dated: 13/4/18

FIRE SAFETY CERTIFICATE

Certified that the **Pinch of spice-Bon Barbecue (Vertex Hospitality)** located at F-90, Vishal Enclave, District Centre, Rajouri Garden, New Delhi-110027 **running on Ground, 1st & 2nd Floor** only in a building comprising Basement, Ground Floor, 1st Floor, 2nd Floor & SPS shed on terrace owned / occupied by Pinch of spice-Bon Barbecue (Vertex Hospitality), was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/EH/2014/1236 dated 23/09/2014. The premises was re-inspected by the officers concerned of Fire Service on 03.04.2018 in the presence of Sh. Ranjeet (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Restaurant) only for **Ground, 1st & 2nd Floor** with effect from 13/4/18 for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/4/18 **at New Delhi by.**


(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Manpreet Singh (Partner), Pinch of spice-Bon Barbecue (Vertex Hospitality), F-90, Vishal Enclave, District Centre, Rajouri Garden, New Delhi-110027.
2. Dy. Health Officer, SDMC (PHD), West Zone, Rajori Garden, New Delhi-110027.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working conditions all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt..nic.in.

1. Name & address of the building: **Pinch of spice Restaurant, F-90, Vishal Enclave, Distt. Centre, Rajouri Garden, New Delhi-110027.**
2. Type of Occupancy : **Assembly**
(G+1st Floor+2nd Floor & SPS shed on terrace)
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/EH/2014/1236 dated 23/09/2014**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **03/04/2018**
7. Name of the Inspecting Officer : **A.D.O. (Jwala Puri) & D.O. (West)**
8. Name and designation of Officer
from the building side : **Sh. Ranjeet (Manager)**
9. Year of construction : **1987**
10. Applicant's letter No. : **- Nil Dated 22/02/2018.**

S. No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtr	09 mtr	MR
	• Gate width	On Road	On Road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr & 1 mtr	G.F. to S.F.=1.20 mtr , G.F to F.F=120 cm to 150 cm varying, F.F. to S.F. 120 cm internal	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	Old Case	GF=2X83cm, 1X75cm, FF=2X109cm, SF=109cm, 95 cm	MR (Old Case)
3.	Compartmentation			
	• Fire check door	NR	NR	NR (Being low-rise)
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	12	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR

	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the pump	40 Meter Head	40 Meter Head	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr	10,000 Ltr	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note :- There is a SPS Shed on terrace used for Kitchen / Residence for workers.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/EH/2014/1236 dated 23/09/2014 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok Kumar Jaiswal
5/4/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Mukesh Verma
5/4/18

Signature of the Inspecting Officer
Name : Mukesh Verma
Designation : D.O. (West)

By WFO (W2)
CS WFO/gy
11/04/18

[Signature]
10/4/18

FT Pls

FIT. is put up for signature please.

A D/O JP
11/04/18

[Signature]