

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2013/707

Dated: 13/04/18

FIRE SAFETY CERTIFICATE

Certified that the M/S Royal Community Hall Mincoha Yogic Shkisha Sanskritic Nyas, at Mandawali Fazalpur, opp. Bathla, CGHS, Patparganj, IP Extension, Delhi - 92, comprised of Basement, ground plus one upper floor owned/occupied by Royal Community Hall, have deemed complied with the Fire prevention and Fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 02/04/2018 in the presence of Sh. Minocha (Owner) and found that the Assembly building is fit for occupancy class "D" 'Assembly (Banquet Hall)' with effect from 13/04/18...for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on.....13/04/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Royal Community Hall,
Mincoha Yogic Shkisha Sanskritic Nyas,
Mandawali Fazalpur, opp. Bathla, CGHS, Patparganj, IP Extension,
Delhi.
2. The Dy. Health Officer,
East Delhi Municipal Corporation, Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi.



CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Royal Community Hall (Mincoha Yogic Shkisha & Sanskritic Nyas, Mandawali Fazalpur, opp. Bathla, CGHS, Patparganj, IP Extension, Delhi.
2. Building is comprised of : B+G+1
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/BNQT/2015/NDZ/403 Dated 20/03/15.
6. Fire Safety direction letter No : F6/DFS/MS/BP/98/575 Dated 20/03/98.
7. Date of Inspection : 02/04/18
8. Name of the Inspecting Officers : DO. F. Brown
9. Name of the designation of Officer
From the building side : Sh. Anoop Minocha
10. Year of Construction : 1998
11. Applicant's letter No : Nil Dated 07/03/2018


S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	24 m	MR
	Gate width	4.5 m	5 m	MR
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02 no.	02 no.	MR
	Basement	02 no.	02 no.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	1.5 m	1.5 m each	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
	g. Width of Corridor	N/A	N/A	N/A
h. Door Size	2.0 m	2.0 m, 1.5, 1.5m	MR	
i. No. of door	2 no.	03 no.	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	Required	Provided	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	Basement	Ventilated	Ventilated	MR
	Upper floor	Ventilated	Ventilated	MR
5.	Fire Extinguisher			
	Total numbers	06 no.	08 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floors	1 nos.	1 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooters	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	100 MM	100MM	MR
	Number of hydrants each floor	01	01	MR
	Hose box each floor	01	01	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 LPM	900 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	10,000 Ltr..	10,000 Ltr.	MR
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	12,500 Ltr.	12,500 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	provided	MR
18	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection system for protection of special Risks, if any	N/A	N/A	N/A

The Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS/2015/403 dated 20/03/2015 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name : F. BROWN
 Designation : DO

Submitted for approval plan.

Dy. CFO (NDZ)

CFO



M. SELL

FIM.

W
9/4

436/cfo/ndz
9/4. 11/4.