

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/NDZ/2018

DMRC/711

Dated: 13/04/18

FIRE SAFETY CERTIFICATE

Certified that the M/S : Krishna Nager Elevated Metro Station building Line -7 Delhi., The Building comprised on a grade level, concourse level, and plate form level, owned / occupied by DMRC. The building was inspected by the officer concerned of this department on 09/3/2018 in the presence of Sh. VP Singh Dy.CEE and others of the premises and found that the "Assembly" building have deemed complied with the Fire prevention and Fire safety requirements in accordance with the rules . The Fire Safety Certificate under rule 35 unless renewed under rule 36 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group "D" "Assembly Building" with effect from 13/04/18...for a period of three years, subject to conditions printed overleaf.

Issued on.....13/04/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

Sh. R K Saxena  
Chief Engineer/ RC-1, DMRC. LTD.  
Laxmi Nager - 4 site office,  
Seed back Park School Block, Shakarpur,  
Delhi-92.

ok  
h

## INSPECTION REPORT

1. Name & address of the building : Krishna Nagar Elevated Metro Station building L-7 Delhi.
2. Building is comprised of : Road level + Concourse level.+ platform floors.
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of Previous FSC : NIL
6. Fire Safety direction letter No : Directive No. F.6/DFS/MS/BP/2013/187 Dated 12/07/13.
7. Date of Inspection : 09/03/18,
8. Name of the Inspecting Officers: : DO. Francis Brown
9. Name of the designation of Officer :  
from the building side : Sh. V. P. Singh Dy CEE. with others
10. Year of Construction : 2018
11. Applicant's letter No : Nil dated. 08.02.18

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	06 m	22 wide Main road	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	06	06	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	06	(4m-01),(2.6m-01) (4.85m-02),(2.85m-02)	MR (50% Cap. of Escalators is counted for evacuation in NFPA)
	Basement			
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5m	1.5m	MR
	h. Door Size	2.0 Mtrs.	2M, & 1.5 M	MR
3.	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	2 hrs.	2 hrs.	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	Natural Ventilated	N/A
5.	Fire Extinguisher			
	Total numbers	10 Nos.	12 Nos.	MR
	types	ABC type & Co2	ABC type & Co2	MR
	IS marking	ISI marked	ISI marked	MR

6.	First-aid-Hose Reels.			
	Total numbers of each floors	03 nos. concourse level 04 nos. platform level	03 nos. concourse level 04 nos. platform level	MR
	Length of hose reel hose	45 m	45 m	MR
	Nozzle diameter	6.5 mm	6.5 mm	MR
7.	Automatic fire detection and alarming system.			
	Type of detectors	Heat or Smoke	smoke	MR
	Location of main panel	G. Floor	G. Floor	MR
	Location of repeater panel	G. Floor	G. Floor	MR
	Alternate source of power	Battery & DG Set	Provided	MR
	Hooters	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public address System.	Required	Provided	MR
10.	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	02 nos. on Road level 03 nos concourse level 04 nos. platform level	02 nos. on Road level 03 nos. concourse level 04 nos. platform level	MR
	Hose box each floor	03 nos.	03 nos.	MR
12.	Yard Hydrants.			
	Total number of hydrants	02	02	MR
	Hose Box	02	02	MR
13.	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	1800 lpm	Provided	MR
	➤ Head of Main Pump	70m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby pump out put	1800 lpm	Provided	MR
	➤ Standby pump Head	70 m	Provided	MR
	➤ Auto Starting /Manual stopping	Auto	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14.	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50000 Ltrs	50000 Ltrs	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	Provided	MR
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19.	Fire Control Room			
	Detector system panel	Required	Provided	MR
	Flow switch panel	Required	Provided	MR
	PA system panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection systems for protection of special Risks, if any:	Required	Provided	MR

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping In view, compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the Directive No. F.6/DFS/MS/BP/2013/187 dated 12/07/13 issued by this department.

The Fire safety certificate issued under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Francis Brown*  
10/3/13

Signature of the Inspecting Officer

Name : Francis Brown

Designation : DO ( East)

Dy. CFO (NDZ)

*5/3*

*Pl take all the certificates from DMRC as done by South Zone.*

*c. & M DCFONDZ/ miscell 19/3*