

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/School/ 2018/736


Dated: 19 / 4 / 2018

**FIRE SAFETY CERTIFICATE**

Certified that the Gurusharan Convent School at GH-9, Paschim Vihar (Near Telephone Exchange) New Delhi-110087, comprised of Basement + Ground + Three Upper Floors only owned / occupied by Gurusharan Convent School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2015/WZ/272 dated 27/02/2015. The premises was re-inspected by the officer concerned of Fire Service on 05.04.2018 in the presence of Mr. Harpreet and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class-B Educational with effect from 19 / 4 / 2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 19 / 4 / 18 at New Delhi by.

  
(ATUL GARG),  
CHIEF FIRE OFFICER,



Copy to :-

1. The Principal, Gurusharan Convent School, GH-9, Paschim Vihar, Near Telephone Exchange, New Delhi-110087.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: **Gurusharan Convent School, GH-9, Paschim Vihar,  
Near Telephone Exchange, New Delhi-110087.**
2. Type of Occupancy : **Educational**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/School/2015/WZ/272 dated 27/02/2015**
5. Fire Safety directives Letter No. : - **DOE circular dated 17/01/2005**
6. Date of inspection : **05/04/2018**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer  
from the building side : **Sh. Harpreet**
9. Year of Construction : **2006**
10. Applicant's letter No. : **Nil dated 14/03/2018**

Basement + Ground + Three  
Upper Floors Only

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE circular dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	On main road	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.60 mtr x 2	MR
	• Basements	1.50 mtr	1.60 mtr x 2	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 mtr	2.25 mtr	MR
	f. Door Size	1.00 mtr	1.25 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	N/A	N/A	N/A

3. Type of Case

: Renewal

4. Details of previous NOC : F6/DFS/MS/School/2015/WZ/272 dated 27/02/2015

5. Fire Safety directives Letter No. : - DOE circular dated 17/01/2005

6. Date of inspection : 05/04/2018

7. Name of the Inspecting Officer : A. K. Jaiswal

8. Name and designation of Officer

from the building side : Sh. Harpreet

9. Year of Construction : 2006

10. Applicant's letter No. : Nil dated 14/03/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE circular dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	On main road	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.60 mtr x 2	MR
	• Basements	1.50 mtr	1.60 mtr x 2	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	1.50 mtr	2.25 mtr	MR
	f. Door Size	1.00 mtr	1.25 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	15	30	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	2	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	M/R
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	One at each floor	One at each floor	MR
	• Hose Box	One at each floor	One at each floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM & 180LPM	450 LPM & 180LPM	MR
	➤ Head of the pump	40 MTR	40 MTR	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank	N/A	N/A	N/A

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	M/R
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	One at each floor	One at each floor	MR
	• Hose Box	One at each floor	One at each floor	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM & 180LPM	450 LPM & 180LPM	MR
	➤ Head of the pump	40 MTR	40 MTR	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.	10,000 Ltr.	M/R

15.	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route .....Clear.....
2. LPG cylinders in laboratories .....Nil.....
3. Electric wiring, Conduit Wiring ..... MCB and ELCB .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F6/DFS/MS/School/2015/WZ/272 dated 27/02/2015** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. (w)

*[Handwritten signature]* 16/4/18

*[Handwritten signature]* 17/4/18

*[Handwritten signature]* P/S

Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : A.D.O. (Jwala Puri)

12.4.18

Signature of the Inspecting Officer

18/4/18

17/4/18

P/S

Signature of the Inspecting Officer