

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2018/

801

Dated:

24/04/18

FIRE SAFETY CERTIFICATE

Certified that **Sai Public School located at WZ- 86A, Todapur Village, New Delhi- 110012**, running at ground floor only of a building comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2007/3348 dated 05.11.2007 (for ground floor only). The school building was re-inspected by the officer concerned of this department on 13.04.2018 in presence of Sh. Reena Kumar, manager of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. 262-362 dated 17-01-2005 and that the school building (**ground floor only**) is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 24/04/18 at New Delhi by.

vk
23/4.
(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The Manager, Sai Public School, WZ- 86A, Todapur Village, New Delhi- 110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Sai Public School located at WZ- 86A, Todapur Village, New Delhi- 110012
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2007/3348 dated 05.11.2007 for ground floor only.
5. Fire Safety directives letter No : N/A
6. Date of inspection : 13.04.2018
7. Name of the Inspecting Officers : M.K.Chattopadhyay, DO(SW)
8. Name and designation of officers from the building side : Sh. Reena Kumar, Manager
9. Year of Construction : Before 2005
10. Applicant's letter No. : 52/SPS/Corresp/P-1 dated 02.04.2018

Sai Public School is running on ground floor only of a building comprised of ground plus two upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire Safety Requirement as per letter dt. 05.11.2007	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts	3.70 mts	MR being old case
	• Gate width	4.5 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mts	0.78 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A

	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	05 nos.	Provided	MR
	• Types	ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	----	N/A	N/A
	• Length of hose reel hose	30 m	N/A	N/A
	• Nozzle diameter	5 mm	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	---	----	-----
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A

	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/2007/3348 dated 05.11.2007 for ground floor only, renewal under the Directorate of Education circular No. 262-362 dated 17.01.2005 is recommended.

Accordingly, DFA is put up please.



423/20/8w
12/04/2018

1.0

[Handwritten signature]
16.11.18