

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2018/ 810

Dated: 24/04/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Central Public School, C-Block, East Of Kailash, New Delhi**, comprised of ground floor only Owned/Occupied by South Delhi Education Society (Regd.) was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/347 dated 21.05.2013. The premises was re-inspected by officer concerned of this department on 11.04.2018 in the presence of Mrs. Avnee Rawat of the school and found that school management have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building is fit for occupancy class "**Educational Building Group-B**" with effect from 23/04/2018 of the issue of this for a period of **Three years** subject to conditions as mentioned below.

Issued on 24/4/18 at New Delhi by

  
Vipin Kental  
Chief Fire Officer  
Ph.: 011-23412225

**Copy to: -**

1. The Principal, **Central Public School, C-Block, East Of Kailash, New Delhi**,
2. The Director of Education, Govt. of NCT of Delhi,  
Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/5

| INSPECTION REPORT |  |   |                         |                       |
|-------------------|--|---|-------------------------|-----------------------|
| 1                 | Name & Address of the Building                                     | Central Public School, C Block East Of Kailash, New Delhi.    |                         |                       |
| 2                 | Type of Occupancy  | Educational Building "Group-B" (School)                       |                         |                       |
| 3                 | Building Comprised of  | Ground Floor only   |                         |                       |
| 4                 | Type of Case   | Renewal   |                         |                       |
| 5                 | Details of Previous NOC  | F6/DFS/MS/School/2013/347 Dated 21/05/2013                    |                         |                       |
| 6                 | Fire Safety Directives Letter No                                   | F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 |                         |                       |
| 7                 | Date of Inspection   | 11.04.2018  |                         |                       |
| 8                 | Name of the Inspecting Officers                                    | ADO R.N. Singh  |                         |                       |
| 9                 | Name & Designation of Officers from the building side              | Ms. Avnee Rawat, Principal                                    |                         |                       |
| 10                | Year of construction   | 1990  |                         |                       |
| 11                | Applicant letter No.   | Nil dated 27/08/2016  |                         |                       |
| <b>S. No</b>      | <b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b> | <b>Directorate of Education Circular Requirements</b>         | <b>Provided at Site</b> | <b>Remarks MR/NMR</b> |
| <b>1</b>          | <b>Access to Building.</b>   |   |                         |                       |
|                   | 1. Road width  | 6 mtr   | 6 Mtr.                  | MR                    |
|                   | 2. Gate width  | NA  | Approachable            | NA                    |
|                   | 3. Width of internal road  | NA  | NA                      | NA                    |
| <b>2</b>          | <b>Number, width, type and arrangements of exits.</b>              |   |                         |                       |
|                   | <b>a. Number of Staircase</b>                                      |   |                         |                       |
|                   | 1. Upper floors  | NA  | NA                      | NA                    |
|                   | 2. Basement floor  | NA  | NA                      | NA                    |
|                   | <b>b. Width of Staircase</b>                                       |   |                         |                       |
|                   | 1. Upper floors  | NA  | NA                      | NA                    |
|                   | 2. Basement floor  | NA  | NA                      | NA                    |
|                   | <b>c. Protection of exits</b>                                      |   |                         |                       |
|                   | 1. Fire check door   | NA  | NA                      | NA                    |
|                   | 2. Pressurization  | NA  | NA                      | NA                    |
|                   | <b>d. No. of continuous staircase to terrace</b>                   | NA  | NA                      | NA                    |
|                   | <b>e. Width of corridor</b>  | NA  | NA                      | NA                    |
|                   | <b>f. Door size</b>  | 1.0 Mtr   | Provided                | MR                    |
| <b>3</b>          | <b>Compartmentation.</b>   |   |                         |                       |
|                   | 1. Fire check door.  | NA  | NA                      | NA                    |
|                   | 2. Sealing of electrical shafts.                                   | NA  | NA                      | NA                    |
|                   | 3. Fire rating of shaft door.                                      | NA  | NA                      | NA                    |
|                   | 4. Water curtain   | NA  | NA                      | NA                    |
|                   | 5. Fire dampers.   | NA  | NA                      | NA                    |
| <b>4.</b>         | <b>Smoke Management system.</b>                                    |   |                         |                       |
|                   | 1. Basement  | NA  | NA                      | NA                    |
|                   | 2. Upper floors  | NA  | NA                      | NA                    |
| <b>5.</b>         | <b>Fire Extinguishers.</b>   |   |                         |                       |
|                   | 1. Total numbers   | ISI Marked  | 5 Nos.                  | MR                    |
|                   | 2. Types   |   | ABC                     | MR                    |
|                   | 3. ISI Marking   |   | Provided                | MR                    |
| <b>6.</b>         | <b>First Aid Hose Reels.</b>                                       |   |                         |                       |
|                   | 1. Total numbers on each floor.                                    | NA  | NA                      | NA                    |
|                   | 2. Length of hose-reel hose.                                       | NA  | NA                      | NA                    |
|                   | 3. Nozzle Diameter   | NA  | NA                      | NA                    |

N/6

|            |  |    |    |    |
|------------|--|----|----|----|
| <b>7</b>   | <b>Automatic Fire Detection and Alarming system.</b> |    |    |    |
|            | 1. Type of detectors                                 | NA | NA | NA |
|            | 2. Location of Main Panel                            | NA | NA | NA |
|            | 3. Location of Repeater Panel                        | NA | NA | NA |
|            | 4. Alternate source of power                         | NA | NA | NA |
|            | 5. Hooter's location                                 | NA | NA | NA |
| <b>8.</b>  | <b>MOEFA /Siren</b>                                  | NA | NA | NA |
| <b>9.</b>  | <b>Public Address System</b>                         | NA | NA | NA |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                    |    |    |    |
|            | 1. Basement  | NA | NA | NA |
|            | 2. Upper floors                                      | NA | NA | NA |
|            | 3. Sprinkler above false ceiling                     | NA | NA | NA |
| <b>11.</b> | <b>Internal Hydrants.</b>                            |    |    |    |
|            | 1. Size of Riser / Down-comer                        | NA | NA | NA |
|            | 2. Number of Hydrant per floor                       | NA | NA | NA |
|            | 3. Hose box.   | NA | NA | NA |
| <b>12.</b> | <b>Yard Hydrants.</b>                                |    |    |    |
|            | 1. Total number of hydrants.                         | NA | NA | NA |
|            | 2. Hose box.   | NA | NA | NA |
| <b>13.</b> | <b>Pumping arrangements.</b>                         |    |    |    |
|            | <b>1. Ground Level</b>                               |    |    |    |
|            | a) Discharge of main pump.                           | NA | NA | NA |
|            | b) Head of main pump.                                | NA | NA | NA |
|            | c) Number of main pumps.                             | NA | NA | NA |
|            | d) Jockey Pump output.                               | NA | NA | NA |
|            | e) Jockey Pump head.                                 | NA | NA | NA |
|            | f) Standby Pump output.                              | NA | NA | NA |
|            | g) Standby pump head.                                | NA | NA | NA |
|            | h) Auto Starting / Manual Stopping.                  | NA | NA | NA |
|            | <b>2. Terrace Level</b>                              |    |    |    |
|            | a) Discharge of pump.                                | NA | NA | NA |
|            | b) Head of pump.                                     | NA | NA | NA |
|            | c) Power supply.                                     | NA | NA | NA |
|            | d) Auto starting of pump.                            | NA | NA | NA |
| <b>14.</b> | <b>Captive water storage for Fire Fighting.</b>      |    |    |    |
|            | 1. Underground tank capacity.                        | NA | NA | NA |
|            | 2. Draw-off connection.                              | NA | NA | NA |
|            | 3. Fire Service Inlet.                               | NA | NA | NA |
|            | 4. Access to tank.                                   | NA | NA | NA |
|            | 5. Overhead tank capacity.                           | NA | NA | NA |
| <b>15.</b> | <b>Exit Signage.</b>                                 | NA | NA | NA |
| <b>16.</b> | <b>Provisions of Lifts.</b>                          |    |    |    |
|            | 1. Pressurization of lift shaft.                     | NA | NA | NA |
|            | 2. Pressurization of lift lobby.                     | NA | NA | NA |
|            | 3. Communication in lift car.                        | NA | NA | NA |
|            | 4. Fireman's switch.                                 | NA | NA | NA |
|            | 5. Lift signage.                                     | NA | NA | NA |
| <b>17</b>  | <b>Standby Power Supply</b>                          | NA | NA | NA |
| <b>18.</b> | <b>Refuge Area</b>                                   |    |    |    |
|            | 1. Total area  | NA | NA | NA |
|            | 2. Location  | NA | NA | NA |

N/7

|  |   |    |   |    |
|--|---|----|---|----|
| <b>19.</b>   | <b>Fire Control Room.</b>   |    |   |    |
|  | 1. Detector System Panel.   | NA | NA  | NA |
|  | 2. Flow Switch Panel.   | NA | NA  | NA |
|  | 3. PA system Panel.   | NA | NA  | NA |
|  | 4. Battery backup   | NA | NA  | NA |
|  | 5. Building floor plan  | NA | NA  | NA |
| <b>20.</b>   | <b>Special Fire Protection System for the Protection of special Risk, if any.</b> |    |   | NA |
| <p>The Fire Protection system provided in the school building were checked and found functional at the time of inspection.</p> <p>In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2013/347 dated 21.05.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended</p> <p>Accordingly DFA is put up for approval and signature please.</p> |   |    |   |    |
|  |   |    | <p><i>R.N. Singh</i><br/>17/4/18</p> <p>Signature of the Inspecting Officer<br/>Name: R.N. Singh<br/>Designation: ADO</p> |    |

Div. Officer (SD)

*Anilash*  
19/4/18

*dy. CFO*

*dy. CFO*  
19/4

1259/CFO S2  
23/4/24/4.

*CFO S2*

*M-Scell*

*FT/102*

*W*  
20/4



*FT letter is put up for sign. please*

*CFO S2*

*M-Scell*

*W*  
24/4

*R.N. Singh*  
23/4