

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/GH/2018/SZ/ 807

Dated: 24/4/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Home@F37** located at F-37, East of Kailash, New Delhi-110065, comprised of basement, ground & 03 upper floors (21 guest rooms) was issued FSC by this department vide letter No. F.6/DFS/MS/GH/2015/SZ/511 dated 09/04/2015 The said premises was re-inspected by officer concerned of this department on 04/04/2018 in presence of Mr. Kalicharan Mehto (Manager) and observed that guest house premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" (Guest House) as above with effect from 24/4/2018 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 24/4/18 at New Delhi by

W
24/4
(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Director, M/s Home@F37 situated at F-37, East of Kailash, New Delhi- 110065
2. The Addl. Comm. of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


INSPECTION REPORT				
1	Name & Address of the Building	M/s 'HOME@F37' Guest House, F-37, EAST OF KAILASH, NEW DELHI-110065		
2	Type of Occupancy	Residential, Group-A (Guest House)		
3	Building Comprised of	Basement, Ground + 03 Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/GH/2015/SZ/511 dated 09-04-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	04-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Kalicharan Mehto (Manager)		
10	Year of construction	1984	Basement (Storage), Gd floor (Rec., lobby & 03 G/rooms), 1 st , 2 nd & 3 rd floor (06 G/rooms on each) Total 21 Guest Rooms.	
11	Applicant letter No.	Nil dated 16-03-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width.	9 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	• Upper floors	02 Nos	02 Nos	MR
	• Basement floor	02 Nos	02 Nos	MR
	b. Width of Staircase			
	• Upper floors.	1.25m	1.10m & 0.70m	MR (old case)
	• Basement floor.	1.25m	0.90m & 0.67m	MR (old case)
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m (final exit)	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain.	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	Required	20 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	35 mtr	35 mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A


The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/GH/2015/SZ/511 dated 09.04.2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: R.N. Singh
 Designation: ADO (BCP)

M/s Home@F37 Guest House, F-37, East of Kailash, New Delhi

DO (SD)


19/4/18

dy. CFO (S2)


19/4

FTM.

CFO S2

M.Scell

20/4.




1260/CFO S2
23/4/24/4.

F.T letter is put up for sign. ple.

CFO/S2

M.Scell

24/4.


23/4