

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2018/SZ/ 806

Dated: 24/4/18

FIRE SAFETY CERTIFICATE

Certified that M/s Locale Restaurant (A Unit of Four Some Foods Pvt Ltd) located at 17, Community Centre, Saket, New Delhi-110017 comprised of basement, ground + three upper floor, restaurant is running on second & third floor was granted FSC by this department vide letter No. F.6/DFS/MS/EH/2015/SZ/422 dated 23/03/2015. The premises was re-inspected by the officer concerned of this department on 11/04/2018 in the presence of Mr. Gurvinder Singh Dham and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D, Assembly Building (Restaurant) with effect from the date of issue of this certificate for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/4/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

- (1) Joint. Commissioner of Police, Licensing, 1st floor, P.S. Defence Colony, New Delhi
- (2) The Director, Locale Restaurant, 17, Community Centre, Saket, New Delhi-110017

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building:- M/S Locale Restaurant(Aunit of Four Some Food Pvt.Ltd)
17,Community Center, New Delhi-110017
2. Type of occupancy:- Assembly, Group – D, Restaurant
3. Type of case:-Renewal
4. Details of previous NOC:- F6/MS/DFS/EH/2015/SZ/422 Dated 23/03/2015
5. Fire safety directives No.- Nil
6. Date of inspection:-11/04/2018
7. Name of the inspecting officer:- R.N.Singh A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Gurvinder Singh Dham
9. Year of construction:- 1988
10. Applicant's letter no:- Nil Dated: 19/03/2018
11. Building comprised of:- Basement, Ground + Three upper floors (Restaurant is running on second and third floor)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As Per Old Noc 2015	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided 24 mtr	MR
	2) Gate width	Required	1.5 mtr Restaurant gate provided	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos	01 Nos	MR Old Case
	2. Basements	01 Nos	01 Nos	MR Old Case
	B. Width of staircase			
	1. Upper floors	1.25 Mtrs	1.19 mtrs	MR Old Case
	2. Basements	1.25 Mtrs	1.19 mtrs	MR Old Case
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01 Nos	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 mtrs	1.5 mtrs	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	1) Total numbers	12 Nos	Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking	ISI Marked	Yes	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	01 Nos	Provided at second & third floor	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01 Nos	Provided	MR
	3) Hose box	01 Nos	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM & 180 LPM	Provided	MR
	b) Head of pump	Required	40 mtrs each	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 Ltrs	5,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR

N/115

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/EH/2015/SZ/422 dated 23/03/2015 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature If approved.

Submitted please.

R.N. Singh
16/4/18

Signature of the inspecting officer
 Name: - R.N.Singh
 Designation:- Assistant Divisional Officer (BCP)

D.O/cb
R. N. Singh
 13/4/18

Dy. CPO (S2)

CFO (S7)

[Signature]
 19/4



1262/cfo S2
 23/4 12/4/18

m.scell

F.T/M

[Signature]
 23/4

F.T letter is put up for sign. please.

cfo/sf

m.scell

[Signature]

24/4