

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax No. 011-23412593, Ph. 011-23412225

No. F6/MS/DFS/Banquet/2018/SZ/ 805

Dated: 24/4/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Ten (A unit of JPS Catering Pvt. Ltd.) located at B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi -110017 comprised of Lower Ground Floor, Ground Floor plus Two Upper Floors, has Banquet Hall at Lower Ground Floor was granted FSC by this department vide letter No.F6/MS/DFS/Banquet/2013/SZ/1360 dated 30/12/2013. The Banquet Hall was re-inspected by the officers concerned of this department on 11/04/18 in the presence of Mr. Rakesh and found that the said Banquet Hall have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the Banquet Hall is fit for occupancy class Group – D Assembly Building (Banquet Hall) with effect from ~~2014/18~~ 24/4/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued.....24/4/18.....at New Delhi.

24/4
Vipin Kental
CHIEF FIRE OFFICER

R.
01/4

Copy to:-

- (1) Dy. Health Officer, SDMC, South Zone, Aurobindo Marg, Green Park New Delhi-110043.
- (2) M/s Ten Banquet, B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi -110017.

Following fire safety directives must be adhered to:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

N-16

1. Name & address of the building:- M/s Ten (A unit of JPS Catering Pvt. Ltd.) B-10, DDA Community Centre, Triveni Complex, Saikh Sarai, New Delhi -110070
2. Type of occupancy:- Group – D, Assembly Building (Banquet Hall)
3. Type of case:- Renwl
4. Details of previous NOC:- F6/MS/DFS/Banqueat/2013/SZ/1360 dated : 30/12/2013
5. Fire safety directives No.- Nil
6. Date of inspection:-11/04/2018
7. Name of the inspecting officer:- R.N.Singh , ADO(BCP)
8. Name & designation of officer
From the building side:- Mr. Rakesh
9. Year of construction:- Nil
10. Applicant's letter No:- Nil
11. Building is comprised of:- Lower Ground floor, Ground plus Two Upper Floors. Banquet hall is at Lower Ground Floor

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As Per Old NOC 2013	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6m	Provided 9m	MR
	2) Gate width	Required	Provided 3 mtr	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Lower Ground Floor/Ground Floor	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Lower Ground Floor/Ground Floor	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 m.	Provided total 05 Nos of exits having width of 2.5m, 1.37 m, 1.37 m, 0.88 & 0.88 m respectively.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements / Lower Ground Floor	30 a/c per hour	Exhaust Fans	MR
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	06 Nos.	MR
	2) Types		ABC & Co ₂	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 Nos.	02 nos. Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement/ Lower Ground Floor	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	Not Required	02 nos. Provided	MR
	2) Hose box	Not Required	Provided	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	180 & 900 LPM	MR
	b) Head of pump	Required	46 mtrs each	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5000 Ltrs	10000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided DG Set	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A

20/18

19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.
 In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures or required under the rules the NOC issued vide letter noF6/MS/DFS/Banquet/2013/SZ/1360 Dated-30/12/2013, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up please.

[Signature]
16/4/18

Signature of the inspecting officer
 Name:- R. N. Singh
 Designation:- Assistant Divisional Officer.

DO (SD)
[Signature]
19/4/18

[Signature]
dy. CPO/S2

[Signature]
19/4



CFO (S4)

FT (D)

M. Scell

[Signature]
23/4

1263/CFO S2
23/4/24/4

F.T letter is put up for sign. *[Signature]*
23/4

CFO/S2

M. Scell *[Signature]*
24/4