

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/837

Dated: 25/4/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Vidya Vihar Shiksha Samiti, E-7, Panchsheel Garden, Naveen Shahdara, Delhi - 110032, comprised of Ground plus three upper floors owned / occupied by Vidya Vihar Shiksha Samiti was issued FSC vide letter No. F6/DFS/MS/2007/659 Dated: 06/03/2007. The school building was re-inspected by the officer concerned of this department on 06/04/18 in presence of Anupam Bhatnagar, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 25/4/18.....for a period three year, subject to conditions printed overleaf.

Issued on 25/4/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

o/c of

Copy to:-

1. Vidya Vihar Shiksha Samiti,  
E-7, Panchsheel Garden, Naveen Shahdara,  
Delhi - 110032.
2. The Dy. Director of Education,  
B-Block, Yamuna Vihar,  
Delhi- 110053.

**- Conditions -**

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

DO/LN

1. Name & address of the building : Vidya Vihar Shiksha Samiti, E-7, Panchsheel Garden, Naveen Shahdara, Delhi - 110032.
2. Building is comprised of : **G+ 3**
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F6/DFS/MS/2007/659 Dated: 06/03/2007.
6. Fire Safety direction letter No : Old requirement (Circular No. 262-362 dated 17/01/05)
7. Date of Inspection : 06/04/2018
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Anupam Bhatnagar (Manager)
10. Year of Construction : 2003
11. Applicant's letter No : CFO/CP/2018/5 Dated - 21/03/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per DDE	Provided at Site	Remark MR/NMR
1	Access to building	06 Mtrs	08 Mtrs	<b>MR</b>
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 no.	02 no.	<b>MR</b>
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	b. Width of Staircases	1.5 m	1.5 m, 1.0 m	<b>MR</b>
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization			
	d. No. of continuous staircases to terrace	01 of	01 of	<b>MR</b>
	e. Width of Corridor	1.5 m	1.5 m	<b>MR</b>
	f. Door Size	1.0 m	1.0 m	<b>MR</b>
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	Ventilated		
	• Basement	N/A	Ventilated	N/A
	• Upper floor	N/A	Ventilated	N/A
5.	Fire Extinguishers			
	• Total numbers	06 nos.	16 nos.	<b>MR</b>
	• types	ABC & Co2	ABC & Co2	<b>MR</b>
	• ISI marking	ISI marked	ISI marked	<b>MR</b>

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	M/R
	➤ Head of the Pump	40 M	40 M	M/R
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 Liters	5000 Liters	M/R
15	Exit Signage.	N/A	Provided	M/R

N/4

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

The Fire safety Certificate issued vide letter no. F6/DFS/MS/2007/659 Dated: 06/03/2007 has grant under circular No. 262-362 dated 17/01/05 is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

*Francis Brown* 9/4/18

Signature of the Inspecting Officer  
Name: Francis Brown  
Designation: ADO (Shahdara)

DO (East) *submitter for approval plan*

*for of*  
18/4/18

*459/06 N/A*  
18/4/18/4.

DCFO/NDZ *[Signature]* F 7/17.

*CFD. M. scell* 18/4.

Sir f.t. letter is put up for your kind signature please.

CF.O (H&P)

*M. scell* 18/4.

*Francis Brown* 18/4/18