

FORM- H]
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SCHOOL/WZ/2018/ 818

Dated: 24/04/2018

FIRE SAFETY CERTIFICATE

Certified that the **Govt Sarvodaya kanya Vidyalaya** Located at **No-2, Shakurpur Delhi-110034** comprised of **Total 03 Blocks** (One BL=G+1 Upper Floor & Two BL=Ground Floor Only)(**Except Auditorium**) was issued FSC vide Letter No.F6/DFS/MS/SCHOOL/2014/WZ/1657 Dated 26-12-2014 The premises was re inspected by the officer concerned of this department on **03-04-2018** in the presence of **Mrs. Madhu Bala Malik (Principal)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 24/04/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on24/04/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-1. **The Principal, Govt Sarvodaya kanya Vidyalaya, No-2, Shakurpur Delhi-110034.**

2. The Directorate of Education Old Secretariat Delhi -110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building:- **Govt Sarvodaya kanya Vidyalaya**
Located at No-2, Shakurpur Delhi-110034
2. Type of Occupancy : Educational Total 03 Blocks(One BL=G+1 Upper Floor & Two BL=Ground Floor Only) *(Except Auditorium)*
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2014/WZ/1657 Date 26-12-2014
5. Fire Safety directives Letter No.: DOE Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 03-04-2018
7. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
8. Name and designation of Officer
9. from the building side : Mrs. Madhu Bala Malik (Principal)
10. Year of Construction : 1959 & 2002
11. Applicant's letter No. : SKVNo2/SP/2018/131 date 13-03-2018

No. of Students=1460
No. of class rooms=37
Plot area=16327.44Sqm
Covered area=9125.98Sqm


S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	5.5 m Provided	MR
		Accessible	360cm Provided	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements 	2	3 Provided	MR
		NA	NA	NA
	<ul style="list-style-type: none"> b. Width of staircases • Upper floors 	150cm	1x145cm&2x170cm Provided	MR
		NA	NA	NA
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> c. Protection of exits • Fire check door • Pressurization 	NA	NA	MR
		NA	NA	MR
	<ul style="list-style-type: none"> d. No of continuous staircase to terrace 	1.5m	152cm Provided	MR
	<ul style="list-style-type: none"> e. Width Of Corridor 	1m	102cm	MR
	<ul style="list-style-type: none"> f. Door Size 			

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	33 nos. ABC & CO ₂ ISI marked	37 provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/SCHOOL/2014/WZ/1657 Date 26-12-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer

Name Vdau Vir Singh

Designation ADSO/w


Signature of the Inspecting Officer

Name

Designation

DSO/w


Inspector 14/4/18
16/4/18
17/04/18

FT/PS

ADSO/w/p

Sir FY letter is put up for sign pl

CSO/ADSO/w 20/4/18



ADSO/w