

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 869

Dated: 27/4/18

FIRE SAFETY CERTIFICATE

Certified that **Guru Harkrishan Public School** at Poorvi Marg, Vasant Vihar, New Delhi, having three blocks, two interconnected blocks comprised of basement, ground plus three upper floors and ground plus three upper floors, third block comprised of basement, ground plus three upper floors owned/occupied by Guru Harkrishan Public School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16/Estate/CC/Fire Safety/2011/398 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and verified by the officers concerned of Delhi Fire Service on 04.04.2018 in the presence of Mr. Joga Singh (Admin) and that the building/premises is fit for occupancy class **'Educational'** Group-A (School upto Sr. Sec. level) with effect from the date of issue of this certificate for a period of **Three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/4/18 at New Delhi by

(Vipin Kental)
Chief Fire Officer

Copy to: -


1. Principal, Guru Harkrishan Public School, Poorvi Marg, Vasant Vihar, New Delhi-110057
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


INSPECTION REPORT				
1	Name & Address of the Building	GURU HARKRISHAN PUBLIC SCHOOL, Poorvi Marg, Vasant Vihar, New Delhi-110057 (ID-1720151)		
2	Type of Occupancy	Educational, 'Group-B' (School)		
3	Building Comprised of	Block-1 & 2 are interconnected, comprised of B+G+3 and G+3, Block-3 comprised of B+G+3		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Cir.F.16//Estate/CC/Fire Safety/2011/3298 to 3398 Dt. 01.03.2011		
7	Date of Inspection	04-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. Joga Singh (Admin)		
10	Year of construction	1974		
11	Applicant letter No.	16496 dated 01-03-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE Circular requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	06 mtr	MR
	• Gate width	-NA-	4.5 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	Bk 1- 3, Bk 2- 2 Nos and Bk 3- 02 Nos	Bk 1- 3, Bk 2- 2 Nos and Bk 3- 02 Nos	MR MR
	➤ Basement floor	Bk 1- 2, Bk 3-2 Nos	Bk 1- 2, Bk 3-2 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.50m / 0.75m	Bk 1- 1.5m, 1.8m, 1.5m Bk 2- 1.6m & 1.6m, Bk 3- 1.6m & 1.45m	MR MR MR
	➤ Basement floor	1.50m / 0.75m	Bk 1- 1.75m & 1.50m Bk 3- 1.45m & 1.35m	MR MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One each block	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement.	30 ACPH	Exhaust fans provided	MR
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	32 No's	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One each block	One each block	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR


7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement.	Required in Bk 1 & 3	Provided	MR
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	a) Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	b) Terrace Level			
	➤ Discharge of pump.	Bk 1&2-900 LPM Bk 3- 900 LPM	Bk 1&2-900 LPM x 2 Bk 3- 900 LPM	MR
	➤ Head of pump.	40 mtr each	40 mtr each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	Bk 1&2-20,000 ltrs Bk 3-15,000 ltrs	Bk 1&2- 20,000 ltrs Bk 3- 15,000 ltrs	MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room.			
	• Detector System Panel.	-NA-	-NA-	-NA-
	• Flow Switch Panel.	-NA-	-NA-	-NA-
	• PA system Panel.	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures required under the Directorate of Education circular, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">  Signature of the Inspecting Officer Name : R.N. Singh Designation: ADO (BCP) </p>				


Guru Harkrishan Public School, Poorvi Marg, Vasant Vihar, New Delhi- 110057

DO (SD)


20/4/18







23/4

CPoS 2)

m.scell


FTM.



25/4

1203/CFR2
27/4.

FT letter is sent up for signature.
CPoS 2

m.scell


26/4


26/4