

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2018/ 873

Dated: 1/5/18

FIRE SAFETY CERTIFICATE

Certified that **New Bloom School located at 16A/4, WEA, Karol Bagh, New Delhi- 110005**, is running at ground plus one upper floor of the building comprised of ground plus two upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/1503 dated 18-08-2015 (for ground and first floor only). The school building was re-inspected by the officer concerned of Delhi Fire Service on 28.03.2018 in the presence of Mr. Harpal Singh Ahluwalia, manager of the school and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" building/premises (ground and first floor only), with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 1/5/18 at New Delhi by.


(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The Principal, New Bloom School, 16A/4, WEA, Karol Bagh, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : New Bloom School, 16A/4, WEA, Karol Bagh, New Delhi-110005.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2015/SZ/1503 dated 18.08.2015
(ground and first floor only)
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28.03.2018
7. Name of the Inspecting Officers : M.K.Chattopadhyay, DO(SW)
8. Name and designation of officers
from the building side : Mr. Harpal Singh Ahluwalia, manager
9. Year of Construction : 1970-71
10. Applicant's letter No. : Form 'J' dated 07.02.2018

School building is comprised of ground plus two upper floors but school is running at ground and first floor only.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety Requirement as per letter dt. 18.08.2015	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6.0 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.5 mts or less & 0.75 mt	0.89, 0.76 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts.	Provided	MR
	h. Door Size	1.0 mt.	1.0 mt.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	----
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	N/A N/A	N/A N/A	N/A N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos. ABC, CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put 	--- N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A

	<ul style="list-style-type: none"> ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		----	-----	-----
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers are provided near elect. Panel.	MR

M/n

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/201/SZ/1503 dated 18.08.2015 (for ground and first floor only), renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

DFA is put up for approval & signature please

DGFO(S2)

[Signature]
4/4/2018

(M.K. CHATTOPADHYAY)
Divisional Officer (SW)

[Signature]
5/4

13/20/18 SW
4/4/18

CFO(S2)

m.s cell

FTM.
[Signature]
18/4.

F.T. letter is put up for Sign. please.



[Signature]
20/4/18

1208/CFO S2
27/4.

CFO/S2

m.s cell

[Signature]
27/4