

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 863

Dated: 27/4/18

FIRE SAFETY CERTIFICATE

Certified that **Rao Mansa Ram Public School** at Plot No. 991/1, Near Oberai Farm, Kapashera, New Delhi-110037 comprised of Basement (storage and activities), Ground plus three upper floors was issued FSC by this department vide letter No. F.6/MS/DFS/School/2015/SZ/274 dated 27/02/2015. The school premises was re-inspected by officer concerned of this department on 09/04/2018 in the presence of Mr. Vikas Yadav (owner) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class '**Educational Building**' as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 27/4/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Rao Mansa Ram Public School at Plot No. 991/1, Near Oberai Farm, Village Kapashera, New Delhi-110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.


INSPECTION REPORT				
1	Name & Address of the Building	Rao Mansa Ram Public School, Plot No. 991/1 Near Oberai Farm, Kapashera, New Delhi-37		
2	Type of Occupancy	Educational 'Group-B' (School)		
3	Building Comprised of	Basement, Ground plus three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/School/2015/SZ/274 Dt. 27-02-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	09-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Vikas Yadav (Owner)		
10	Year of construction	2002		
11	Applicant letter No.	465/RMRPS/2017-18 dated Nil		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	02 Nos	Provided	MR
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.90m	2m & 1.10m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01 No	Provided	MR
	e) Width of corridor	1.5m	1.5m	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	20 Nos	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 m	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

Rao Mansa Ram Public School, Plot No-991/1, Near Oberai Farm, Kapashera, New Delhi

19.	Fire Control Room.		N/A	N/A	N/A
		• Detector System Panel.	N/A	N/A	N/A
		• Flow Switch Panel.	N/A	N/A	N/A
		• PA system Panel.	N/A	N/A	N/A
		• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A	
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Two ABC type (5 kg) fire extinguisher & four fire bucket with dry sand & stand provided near electrical panel	MR	


The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under Directorate of Education circular, Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2015/SZ/274 dated 27/02/2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


Accordingly, DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: R.N. Singh
 Designation: ADO (BCP)

Rao Mansa Ram Public School, Plot No-991/1, Near Oberai Farm, Kapashera, New Delhi

DO (SD)


13/4/18





16/4



CFO/S2

m.scell

FT/01


25/4

FT letter is put up for sign pls 
26/4

 m.scell 
26/4



1294/CFO S2
26/4 27/4/18