

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/GH/2018/SZ/ 772

Dated: 20/4/18

**FIRE SAFETY CERTIFICATE**

Certified that M/s Sandeep Holiday Inn Guest House located at F-3/22, Vasant Vihar, New Delhi, comprised of Basement, Ground plus two upper floors (22 Guest Rooms) was issued FSC by this department vide letter No. F.6/DFS/MS/GH/2015/SZ/438 dated 26/03/2015. The premises was re-inspected by officer concerned of this department on 27/03/2018 in presence of Mr. BS Ahuja and observed that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class 'Residential' Group-A, (Lodging & Rooming House) as above with effect from 20/4/2018 for a period of **Three years** subject to compliance of the conditions mentioned below

Issued on 20/4/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Addl. Comm. of Police (Lic.), 1st Floor, P.S. Defence Colony, New Delhi-110049
2. M/s Sandeep Holiday Inn Guest House, F-3/22, Vasant Vihar, New Delhi-110057

**Conditions for the validity of Fire Safety Certificate**


1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	M/s Sandeep Holiday Inn Guest House, F-3/22, Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Residential, Group-A (Guest House)		
3	Building Comprised of	Basement, Ground + 02 Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/GH/2015/SZ/438 dated 26-03-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	27.03.2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. BS Ahuja (Manager)		
10	Year of construction	1992		
11	Applicant letter No.	1269/Addl. CP/Lic. (H) dated 22-02-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width.	9 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a. Number of Staircase</b>			
	• Upper floors	Required	One	MR (old case)
	• Basement floor	Required	One	MR (old case)
	<b>b. Width of Staircase</b>			
	• Upper floors.	1.25m	1.30 mtr	MR
	• Basement floor.	1.25m	1.30 mtr	MR
	<b>c. Protection of exits</b>			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1.0m	1.0m (final exit)	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain.	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH0	N/A	N/A
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	10 No's	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

M/s Sandeep Holiday Inn Guest House at F-3/22, Vasant Vihar, New Delhi


<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	<b>Required</b>	<b>Provided</b>	<b>MR</b>
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	<b>Required</b>	<b>Provided</b>	<b>MR</b>
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants.</b>			
	• Size of Riser / Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
<b>13.</b>	<b>Pumping arrangements.</b>			
	• <b>Ground Level</b>			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• <b>Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	35 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for Fire Fighting.</b>			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltr.	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	<b>Required</b>	<b>Provided</b>	<b>MR</b>
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
<b>17</b>	<b>Standby Power Supply</b>	<b>Required</b>	<b>Provided (DG Set)</b>	<b>MR</b>
<b>18.</b>	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

N/25

19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	N/A	N/A
<p>The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/GH/2015/SZ/438 dated 26/03/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p> <p style="text-align: right;">   Signature of the Inspecting Officer  Name: R.N. Singh  Designation ADO (BCP) </p>				

M/s Sandeep Holiday Inn Guest House at F-3/22, Vasant Vihar, New Delhi

DO (SD)

  
9/4/18