

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2018/

petl/852

Dated:

26/04/18

FIRE SAFETY CERTIFICATE

Certified that the Shaheed Sumeet Roy Enterprises (Dealer : Indian Oil Corporation Ltd.) located at Sector-24, Rohini, Delhi-110085 comprised of Ground Floor only owned / occupied by Shaheed Sumeet Roy Enterprises, was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/Petl./2015/WZ/1527 dated 21/08/2015. The premises was re-inspected by the officer concerned of Fire Service on 12.04.2018 in the presence of Sh. Vinod Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Hazardous (Group-J) 40 K.L Class 'A' & 70 K.L Class 'B'" with effect from *26/04/18* for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on

26/04/18

at New Delhi by.

(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Authorized Signatory, Shaheed Sumeet Roy Enterprises (Dealer : Indian Oil Corporation Ltd.) Sector-24, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. Work under procurement / installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

416
INSPECTION REPORT

UG Tank of 40 K.L. Petroleum Class 'A', UG Tank of 70 K.L. Petroleum Class 'B' (Ground Floor Only)

1. Name & address of the building: **Shaheed Sumeet Roy Enterprises, Sector-24, Rohini, New Delhi.**
2. Type of Occupancy : **Group J Hazardous Building**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/Petl./2015/WZ/1527 dated 21/08/2015**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **12/04/2018**
7. Name of the Inspecting Officer : **A.D.O. (Jwala Puri)**
8. Name and designation of Officer from the building side : **Sh. Vinod Kumar (Manager)**
9. Year of construction : **2000**
10. Applicant's letter No. : **- Nil Dated 12/03/2018**

| S. No | Minimum standards on fire prevention and fire safety U/R 33 | NBC (Part-IV) Requirements | Provided at site | Remarks MR/NMR |
|-------|---|-----------------------------------|---------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | 28 mtr | MR |
| | • Gate width | Accessible | Accessible Directly | MR |
| | • Width of internal road | --- | --- | --- |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | NA | NA | NA |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | NA | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 1.00 mtr | 1.00 mtr | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NR | NR | NR |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 02 foam of 9 ltr + 01 Co2 4.5 ltr | 23 | MR |
| | • Types | ISI marked ABC/CO ₂ | Provided | MR |
| | • IS marking | Required | Provided | MR |

21/8

| | | | | |
|-----|--|-----|-----|-----|
| 6. | First - Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | N/A | N/A | N/A |
| | ➤ Head of main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Staring/Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw of connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank | NA | NA | NA |

M/S

| | | | | |
|-----|--|--|-----|-----|
| 15. | Exit Signage | NA | NA | NA |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | N/A | N/A | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | N/A | N/A | N/A |
| | ➤ Flow Switch Panel | N/A | N/A | N/A |
| | ➤ PA System Panel | N/A | N/A | N/A |
| | ➤ Battery backup | N/A | N/A | N/A |
| | ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen in premises. | | |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Petl./2015/WZ/1527 dated 21/08/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~Dy CTO / WZ~~ 16/4/18

~~CTO West~~ Area belong to ADO (RW) 16/04/18

~~ADO (RW)~~ ADO (R.O.) was on site

~~ADO (RW) CTO West~~ 16/04/18

F.T. is added for sign. pl.