

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/EH/2018/SZ/ 916

Dated: 4/5/18

FIRE SAFETY CERTIFICATE

Certified that the Yo Yo Bar (A Unit of Yo Yo Restro & Party Lounge) Situated at First Floor of a building comprised of ground plus three upper floor located at Plot No.25, Sector-20, Dwarka, New Delhi-110075, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and verified by the officer concerned of Fire Service on 1.5.2018 in presence of Sh. Bhavesh Yadav (Partner) and that the premises is fit for occupancy 'Assembly building' Group-D (Restaurant) with effect from for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed over leaf.

Issued on at New Delhi by

VC
4/5
(Vipin Kehtal)
Chief Fire Officer
Delhi Fire Service
SC
SM

Copy to:-

1. The Additional Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defense Colony, New Delhi,
2. The DHO, Najafgarh Zone, SDMC Public Health Department, Room No. 408, Zonal Officer Building, Near Dhansa stand, New Delhi.
3. Sh. Bhavesh Yadav s/o Sh. Ramesh kumar Yadav R/o H.N. 47, Dwarka Sector-8, Bagdola Village, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S Yo Yo Bar (A Unit of Yo Yo Resto & Party Lounge) Situating at 1st Floor, Unit No. F-1 to F8, Plot No. 25, Sector-20, Dwarka, New Delh.		
2	Type of Occupancy	Assembly "D" Restaurant (At First Floor)		
3	Type of case	New		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	BBL-1983/NBC 2005 Part IV		
6	Date of inspection	1.5.2018		
7	Name of the inspecting Officers	S.P Bhardwaj ADO Dwarka		
8	Name and designation of officers from the building side	Sh. Bhavesh Yadav (Partner)		
9	Year of construction	Before 2010	Building comprised of Ground + 3 upper Floors	
10	Applicant's letter No.	1576/ Addl./CP/Lic./EH (DA-1) dated 6.4.2018		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/ NBC Requirements	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 Mtrs.	2 Mtrs. & 1.25 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Requied	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	2 Mtrs. (2 Nos.)	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
		12 a/c per hour		
	upper floors		Exhaust fan provided	MR

	total numbers	4 Nos. CO2 OR	5 Nos.	MR
	Types	ABC ISI	ABC	MR
	ISI marking	Marked	ISI Marked	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Heat & Smoke	MR
	location of Main Panel	N/A	Near Entry	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Battery backup	Battery backup	MR
	hooter's location	Near entry	Near Entry	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	Provided in restaurant	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	One at 1st floor	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	Provided	MR
	b. head of the pump	30 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. lift signage	N/A	N/A	N/A

N/7

17	Standby power supply	Required	DG Set	MR
18	Refuge Area.		Not Required	
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: extinguisher provided near electric panel.		ABC fire MR	

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire Safety Certificate is recommended under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

Sury
11/5/18
S.P Bhardwaj
ADO (DWARKA)

Dofsw on leave

Dcfo / S2

*1318/CF/S2
2/5/18*



kgp
2/5

FT/06
U
3/5

cfos 37

m.scell

FT to put up for signature please

Sury
4/5/18

cfos 2

m.scell *U* 4/5