

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2018/ *gdr*

Dated: *03/05/2018*

FIRE SAFETY CERTIFICATE

Certified that **D.I. Khan B.S. Sr. Sec. School, R-Block, New Rajinder Nagar, New Delhi- 60**, comprised of ground floor only was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2011/2731 dated 28.10.2011. The school building was re-inspected by the officer concerned of this department on 06.04.2018 in presence of Mrs. Rekha Rana, principal of the school and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on ----- *03/05/18* ----- at New Delhi by.

W 2/5
(VIPIN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The Principal, D.I. Khan B.S. Sr. Sec. School, R-Block, New Rajinder Nagar, New Delhi- 60.
2. The Commissioner, SDMC, Civic Centre, Minto road, NewDelhi-110002.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : D.I. Khan B.S. Sr. Sec. School, R-Block, New Rajinder Nagar, New Delhi- 110060.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2011/2731 dated 28/10/2011
5. Fire Safety directives letter No : Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011.
6. Date of inspection : 06.04.2018
7. Name of the Inspecting Officers : M.K. Chattopadhyay, Divisional Officer (South West)
8. Name and designation of officers from the building side : Mrs. Rekha Rana, Principal
9. Year of Construction : Before 2007
10. Applicant's letter No. : Form 'J' dated 16.03.2018.

D.I. Khan B.S. Sr. Sec. School is comprised of ground floor only

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per letter dt. 28.10.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	N/A N/A	N/A N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos. ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	---- 30 m 5 mm	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system Not required			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put 	--- N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A

	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	----	-----	-----
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. Not Applicable			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	Required	01 ABC type fire extinguisher is provided near elect. Panel.	MR

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/School/2011/2731 dated 28/10/2011, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

DFA is put up for approval & signature please



Handwritten signature
9/4/18

Signature of the Inspecting Officer
(M.K. CHATTOPADHYAY)
Divisional Officer, (South West)

DCFO

Handwritten signature
9/4

CFO S.W.

Pl speak w/ 18/4.

DCFO S.W.
DO(SW)

361/DO(SW)
09.04.2018

1246/CFO SW
19/4/18

Necessary correction is made in door size. Submitted for approval please.

Handwritten signature
23/4/18

CFO (South)

Miscell

F.T.M.

w/ 25/4.

F.T. letter is put up for Sign. please.

CFO (South)

Miscell

w/ 25.

Handwritten signature
26/4/18