

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/EH/2018/SZ/ 944

Dated: 8/5/18.

**FIRE SAFETY CERTIFICATE**

Certified that M/s **My Square** (A Unit of Versatile Food Courts Pvt. Ltd.) at Shop No. S-01, 2<sup>nd</sup> Floor, Select City Walk Mall, Saket, A-3, District Centre, New Delhi-110017, building comprised of basement, ground + two upper floors, the restaurant running at 2<sup>nd</sup> floor of the building was issued FSC by this department vide letter No. F.6/DFS/MS/EH/2015/SZ/287 Dated 27/02/2015. The premises was re-inspected by the officer concerned of this department on 04.04.2018 in the presence of Mr. Rohit Bakshi (Manager) of the restaurant and observed that the restaurant premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class '**Assembly**' Group-D (Restaurant) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 8/5/18 at New Delhi by

  
**Vipin Kental**  
**Chief Fire Officer**

Copy to: -

1. Auth. Signatory, M/s My Square (A Unit of Versatile Food Courts Pvt. Ltd.) at S-01, 2<sup>nd</sup> floor, Select City Walk Mall, A-3, District Centre, Saket, New Delhi-110017
2. The DHO (SZ), S.D.M.C. Health Department, Aurobindo Marg, Green Park, New Delhi.

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



INSPECTION REPORT				
1	Name & Address of the Building	M/s MY SQUARE at Shop No. S-01, 2 <sup>nd</sup> Floor, Select City Walk Mall, A-3, Distt. Centre, New Delhi. (A Unit of Versatile Food Courts Pvt. Ltd)		
2	Type of Occupancy	Assembly 'Group-D' (Restaurant)		
3	Building comprised of	Basement, Ground plus two upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/EH/2015/SZ/287 Dated 27-02-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	04-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rohit Bakshi (Manager)		
10	Year of construction	2007	Restt running at 2 <sup>nd</sup> floor of the bldg	
11	Applicant letter No.	Nil dated 09-02-2018		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>	<b>F.6/DFS/MS/Mall/2018/SZ/585 Dt. 04/04/2018</b>		
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Restt within Select City Mall Bldg	As above As above As above	MR N/A N/A
2	<b>Number, width, type &amp; arrangement of exits</b>	<b>Provided &amp; Maintained by Mall</b>		
	<b>a. Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	02 Nos N/A	Provided near Restt. As above	MR N/A
	<b>b. Width of Staircase</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.5m N/A	1.52m & 1.16m As above	MR N/A
	<b>c. Protection of exits</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	N/A N/A	As above As above	N/A N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	As above	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	2m	Open front & 4 exits towards open terrace	MR
3	<b>Compartmentation.</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	N/A N/A N/A N/A N/A	As above As above As above As above As above	N/A N/A N/A N/A N/A
4.	<b>Smoke Management system.</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	N/A Exhaust fans Provided	N/A MR
5.	<b>Fire Extinguishers.</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>		10 No's ABC, Co2 & Foam Provided	MR MR MR
6.	<b>First Aid Hose Reels.</b>	<b>Provided &amp; Maintained by Mall</b>		
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>		2 nos provided near Restt. Provided Provided	MR MR MR

M/s My Square Restt at Shop No-01, 2<sup>nd</sup> floor, Select City Walk Mall, Saket, New Delhi



7	<b>Automatic fire detection &amp; alarming system.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Type of detectors	Required	As above	MR
	• Location of Main Panel	Required	As above	MR
	• Location of Repeater Panel	N/A	As above	N/A
	• Alternate source of power	Required	As above	MR
	• Hooter's location	Required	As above	MR
8.	<b>MOEFA</b>	Required	As above	MR
9.	<b>Public Address System</b>	N/A	As above	N/A
10.	<b>Automatic Sprinkler System</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Size of Riser/Down-comer	N/A	N/A	N/A
	• Number of Hydrant per floor	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• <b>Ground Level</b>	<b>Provided &amp; Maintained by Mall</b>		
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting / Manual Stopping.	N/A	N/A	N/A
	• <b>Terrace Level</b>	<b>Provided &amp; Maintained by Mall</b>		
	➤ Discharge of pump.	Required	As above	MR
	➤ Head of pump.	Required	As above	MR
	➤ Power supply.	Required	As above	MR
	➤ Auto starting of pump.	Required	As above	MR
14.	<b>Captive water storage for Fire Fighting.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	Required	As above	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Pressurization of lift shaft.	N/A	As above	N/A
	• Pressurization of lift lobby.	N/A	As above	N/A
	• Communication in lift car.	N/A	As above	N/A
	• Fireman's switch.	N/A	As above	N/A
	• Lift signage.	N/A	As above	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	<b>Provided &amp; Maintained by Mall</b>		
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

M/s My Square Restt at Shop No-01, 2<sup>nd</sup> floor, Select City Walk Mall, Saket, New Delhi

N/14

19.	Fire Control Room.	Provided & Maintained by Mall		
		Required	As above	MR
	• Detector System Panel.	Required	As above	MR
	• Flow Switch Panel.	Required	As above	MR
	• PA system Panel.	N/A	As above	N/A
	• Battery backup	Required	As above	MR
	• Building floor plan	N/A	As above	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any :	N/A	N/A	N/A

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2015/SZ/287 dated 27.02.2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*R.N. Singh*  
28/4/18

Signature of the Inspecting Officer  
Name : R.N. Singh  
Designation: ADO (BCP)

M/s My Square Restt at Shop No-01, 2<sup>nd</sup> floor, Select City Walk Mall, Saket, New Delhi

DO (SD)

*Anilam*  
23/4/18

*Dy. CPO*

*24/4*

*CFO*

*m.s cell*

*FT/101*

*27/4*



*13/4/CF R*  
*4/5/15*

*A. B.T. letter put up for Signature of Home*  
*ADP (S) 2/5/18*

*CPO (S)*

*m.s cell*  
*4/5*