

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

NO.F6/DFS/MS/School/2018/SZ/ 966

Dated: 9/5/18

FIRE SAFETY CERTIFICATE

Certified that the J R Public School, K-351/P-14, Shiv Puri, Gali No.2, West Sagarpur, New Delhi-110046, comprised of ground plus two upper floor was issued Fire Safety Certificate By this department vide letter no. F6/DFS/MS/School/2015/SZ/2266 dated 31.12.2015. The said school building was re-inspected by the officer concerned of this department on 25.4.2018 in presence of Ms. Sushila Girsey (Manager) and found that premise have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular dated 17.01.2005 and that the building is fit for occupancy class B "Educational building" with effect from.....9/5/18... for a period of **three** years, subject to compliance of the conditions printed overleaf.

Issued on8/5/18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer



Copy to:-

1. The Director (Education) GNCT of Delhi, Old Secretariat, New Delhi.
2. Manager, J R Public School, K-351/P-14, Shiv Puri, Gali No.2, West Sagarpur, New Delhi-110046.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	J R Public School, K-351/P-14, Shiv Puri, Gali No.2, West Sagarpur, New Delhi-110046.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+2)		
4	Details of previous NOC	F6/DFS/MS/School/2014/SZ/2266 31.12.2015		
5	Fire safety directives letter No	Directorate of Education Circular no. 262 - 362 dated 17.1.2005		
6	Date of inspection	25.4.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Ms. Sushila Girsey (Manager)		
9	Year of construction	2008		
10	Applicant's letter No.	JRPS/138/2018	Ground plus two upper floor	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE CIR. 17.1.2005	Provided at site	Remarks MR / NMR
--------	---	--------------------	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.50 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 No.	2 No.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr. If less than 1.50 Mtr. Additional staircase of .75 Mtr.	1.30 & .90 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr.	1Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	12 a/c charge	Natural Ventilation	MR

5	Fire Extinguishers			
	total numbers	One No. CO2 OR ABC for every 300 Sq.Mtrs.	7 Nos.	MR
	Types	ISI Marked	ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 & 180 Lpm.	Provided	MR
	b. head of the pump	40 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Lts.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

9/8/18

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire extinguisher provided near electric meter.	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE CIR. dated 117.1.2005, renewal of FSC issued vided letter no.F6/DFS/MS/School/2015/SZ/2266 dated 3.12.2015 is recommended

Accordingly DFA is put up for approval and signature please.

Sent
25/4/18

S.P. Bhardwaj
ADO (Dwarka)

DO/SW
444/DO/SW
dt-26/04/18

DO/SW
26/4/18

DCFO (S2)

124/CF S2
215-98

CFOS2

m.scell

FTM.
Ue
4/5



FT is put up for signature please.

Sent
8/5/18

CFOS2

m.scell
Ue
9/5