

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/ 956

Dated: 8/5/18

FIRE SAFETY CERTIFICATE

Certified that M/s Little Star Public School located at New Chauhanpur, Karawal Nagar Road, Delhi-110094, comprised of ground plus two upper floors only owned/occupied by Little Star Public School was issued FSC vide letter No. F6/DFS/MS/School/2014/NDZ/1519 dated 04/12/14. The school building was re-inspected by the officer concerned of this department on 23/04/2018 in the presence of Mr. R. N. Sharma, Chairman of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. 262- 362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 8/5/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 8/5/18 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

To,  
The Chairman  
M/s Little Star Public School,  
New Chauhanpur, Karawal Nagar,  
Delhi-110094,

Copy:-  
The Dy. Director of Education,  
B- Block, Yamuna Vihar  
Delhi

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

N/7

1. Name & address of the building : Little Star Public School,  
New Chauhanpur, Karawal Nagar Rd, Delhi-94
2. Building is comprised of : Ground plus two upper floors
3. Type of Occupancy : Educational  
Type of Case : **Renewal**
4. Details of Previous NOC letter : F6/DFS/MS/School/2014/NDZ/1519 dated 04/12/14
5. Fire Safety direction letter No : Circular No. 262-362 dated 17/01/2005 (DoE)
6. Date of Inspection : 23/04/18
7. Name of the Inspecting officers : ADO Vijay Bahadur
8. Name and designation of Officer  
from the building side : Mr. R. N. Sharma (Chairman)
9. Year of Construction : 1998
10. Applicant's letter No : 8-L.S.P.S/DFS/18, Dated- 05/04/2018

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	06 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 No.	02 Nos.	MR
	• Basement	N/A	N/A.	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr.	01 mtr & 1.04 mtr mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	02 No.	02 No.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	11 nos.	11 nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos.	01 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	180 Lpm	180 Lpm	MR
	• Jockey pump head	40 M	40 M	MR
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm.	450 Lpm.	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Required	MR
	• Auto starting of pump	Required	Required	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 Ltr.	5,000 Ltr.	MR
15	Exit Signage.	Required	Required	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular No. 262-362 dated 17/01/2005 issued by Director of Education, it is recommended to renew Fire Safety Certificate.

*[Signature]*  
24/4/18  
Signature of the Inspecting Officer  
Name :- Vijay Bahadur  
Designation :- A.D.O (TP)

DO(ED)  
*[Signature]*  
20/4/18

DYCB/ND4  
*[Signature]*

5011/06/ND2  
4/5/18

CF. D. M. Scell FT. B. U. S. 4/5.

As approved FT RSC is put up for signature please.

*[Signature]*  
7/5/18

eFO (ND2)  
M. Scell U. S. 8/5.