

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 943

Dated: 8/5/18.

FIRE SAFETY CERTIFICATE

Certified that the M/s Ideal Palace Community Hall at 32 X-PSP-18 Kakardooma Institutional area, Delhi-92, owned / occupied by Ideal Educational & Welfare Society, comprised of basement, ground plus three upper floors was issued FSC vide Letter No-F.6/DFS/MS/2014/NDZ/1625 Dated 23/12/14. The building was re-inspected by the officer concerned of this department on 07/04/18 in presence of Sh. Kailash Sharma (secretary) and found that the Community hall building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D "Assembly Building" with effect from ..8.5.18.... for a period of three years, subject to conditions printed overleaf.

Issued on.....8/5/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer



To,
Sh. Kailash Sharma (Secretary)
Ideal Palace Community Hall
32 X-PSP-18 Kakardooma Institutional area,
Delhi- 92.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Ideal Palace Community Hall at 32 X-PSP-18, Kakardooma Institutional Area, Delhi-92.
2. Building is comprised of : **Basement, Ground + 3 upper floors.**
3. Type of Occupancy : Community Hall (Assembly Building)
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F.6/DFS/MS/2014/NDZ/1625 Dated 23/12/14
6. Fire Safety direction letter no. : F6/MS/DFS/BP/2002/2425 Dated: 17/12/2002
7. Date of Inspection : 07/04/2018
8. Name of the Inspecting officers : ADO Omprakash
9. Name and designation of Officer from the building side : *Kailash Sharma*
11. Year of Construction : 2002
12. Applicant's letter No : NIL dated 27.02.2018.

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement <i>as per FSC issued on 23.12.14.</i>	Provided at Site	Remark MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs 4.5 Mtrs N/A	18 Mtrs 5 Mtrs N/A	MR MR N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 nos. 02 nos.	02 nos. 02 nos.	MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.25 Mtrs 1.25 Mtrs	1.25 & 1.20 M 1.25 & 1.20 M	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	e. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 m	1.5 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	Required Required 02 hrs. N/A N/A	Provided Sealed 02 hrs. N/A N/A	MR MR MR N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required N/A	Provided N/A	MR N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types • ISI marking 	08 nos. ABC & Co2 ISI marked	10 nos. ABC & Co2 ISI marked	MR MR MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat or smoke	Smoke	MR
	• Location of main panel	Control room	Ground floor	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Staircase	Provided	MR
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	900 LPM	900 LPM	MR
	➤ Head of Main Pump	39 Mtrs.	39 Mtrs.	MR
	➤ Number of main pumps	01 No.	01 No.	MR
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	39 Mtrs.	39 Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltrs.	5,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

2/11

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules, it is recommended to renew Fire Safety Certificate.

Om Prakash
11/4/18

Signature of the Inspecting Officer

Name: Om Prakash

Designation: ADO/Shahdara

submitted for approval please.

DO (East)

for
13/4

DESO/npz

FT/10.

ve
19/4.

CFO. M.Scell

Sir FT. Letter is put up for your kind signature please

CFO (H/O)

M.Scell *ve*
15.

Om Prakash
24/4/18