

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2018/WZ/983

Dated: 10/5/2018

FIRE SAFETY CERTIFICATE

Certified that **Govt. Boys Sr. Sec. School, U-Block, Mangol Puri, Delhi- 110083** comprised of **02 Blocks, Ground & first Floor** owned/occupied by **Govt. Boys Sr. Sec. School**, was issued fire safety certificate vide letter no **F6/DFS/MS/2015/School/WZ/40** dated **08/01/2015**. The premises was re-inspected by the officer from this department on dated **27/04/2018** in the presence of **Sh. G.K. Gupta (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter dated 01/03/2011 and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of **Group Class B_(Educational)** with effect from 10/5/2018 for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/5/18 at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Govt. Boys Sr. Sec. School, U-Block, Mangol Puri, Delhi- 110083
2. The Director of Education, Old Secretariat, Delhi.

INSPECTION REPORT**02 Blocks, Ground + First Floors**

1. Name & address of the building: Govt. Boys Sr. Sec. School, U- Block, Mangol Puri, Delhi
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/School/WZ/40 dated 08/01/2015
5. Fire Safety directives letter No : Director of Education dated 01/03/2011
6. Date of inspection : 27/04/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. G.K. Gupta (Principal)
9. Year of Construction : 1983
10. Applicant's letter No. : GBSSS/MP/U Blk/2018/3326 dated 31/03/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	6 mtr	M/R
	• Gate width	4.5 mtr	4.5 mtr	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	M/R
	• Basements	N.A.	N.A.	N.A.
	b. Width of staircases			
	• Upper Floors	A Block 1.5 mtr B Block 1.5 mtr	A Block 1.5 mtr B block (1) 1.42 cm, (2) 1.49/1.50 cm (3) 1.44 cm	M/R
	• Basements			M/R
	c. Protection of exits	N.A.	N.A.	N.A.
	• Fire check door			
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door Size	N.A.	N.A.	N.A.
		1 mtr	All rooms provided double door	M/R

3	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N.A.	N.A.
		12 a/c per hour	N.A.	N.A.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	11 ISI marked	11 ABC Yes	M.R M.R M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N.A. N.A. N.A.	N.A. N.A. N.A.
		30 m		
		5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N.A. N.A. N.A.	N.A. N.A. N.A.	N.A. N.A. N.A.
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N.A. N.A. N.A.	N.A. N.A. N.A.	N.A. N.A. N.A.

12	Yard Hydrants.			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting / Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access			
	• Terrace level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the pump	N.A.	N.A.	N.A.
	➤ Power Supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.

18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/2015/School/WZ/40 dated 08/01/2015** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

RK
2/5

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

Dy CFO/WZ

[Signature]
7/5/18