

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/ 2018/1001

Dated: 10/5/2018

FIRE SAFETY CERTIFICATE

Certified that the A-41, Mangolpuri, Block-A, Industrial Area, Phase-II, Delhi-110083, Comprised of Ground + Mezzanine + First Floor only owned / occupied by Mr. Anil Wadhawan was issued FSC by this office vide letter No. F6/DFS/MS/2015/WZ/787 Dated 18/05/2015. The premises was re-inspected by the officers concerned of this department on 25/04/2018 in the presence of Mr. Gurvinder Singh (Associate Vice President) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy class "Business Building" (Bank Chest) with effect from 10 / 5 / 2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 10.5.18 at New Delhi.

(ATUL GARG)

CHEF FIRE OFFICER

Copy to :- 1. Mr. Gurvinder Singh (Associate Vice President), A-41, Mangolpuri, Block-A, Industrial Area, Phase-II, Delhi-110083.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N/114
INSPECTION REPORT

1. Name & address of the building: **A-41, Mangolpuri, Block-A, Industrial Area, Phase-II, Delhi-110083.**
2. Type of Occupancy : Business Building Bank Chest (Ground, Mezzanine & 1st floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/787 Dated 18/05/2015
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2012/711 dated 29/02/2012
6. Date of inspection : 25/04/2018
7. Name of the Inspecting Officer : A.K. Jaiswal (A.D.O. JWP)
8. Name and designation of Officer
from the building side : Mr. Gurvinder Singh (Associate Vice President)
9. Year of Construction : 1992
10. Applicant's letter No. : Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	6 mtr	6 mtr		MR
	• Gate width	4.5 mtr	4.5 mtr		MR
	• Width of internal road	NR	NR		NR
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	2	2		MR
	• Basements	NR	NR		NR
	b. Width of staircases				
	• Upper floors	1.25 mtr & 1.50 MTR	1.25 mtr & 1.50 MTR		MR
	• Basements	NR	NR		NR
	c. Protection of exits				
	• Fire check door	Required	Provided		MR
	• Pressurization	NR	NR		NR
	d. No of continuous staircase to terrace	NR	NR		NR
	e. Width Of Corridor	1.50 mtr	1.50 mtr		MR
	f. Door Size	1.00 mtr	1.25 mtr		MR
3.	Compartmentation				
	• Fire check door	Required	Provided		MR
	• Sealing of electrical shafts	NR	NR		NR
	• Fire Rating of shaft door	NR	NR		NR
	• Water Curtain	NR	NR		NR
	• Fire Dampers	NR	NR		NR
4.	Smoke managements System				
	• Basements	NR	NR		NR
	• Upper floors	Required	Provided		MR
5.	Fire Extinguishers				
	• Total numbers	6	6		MR
	• Types	ISI marked ABC/CO ₂ /WCO ₂	Provided		MR
	• IS marking	Required	Provided		MR



21/7/15

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30Mtr.	30Mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	Provided	NR
	• Location of Main Panel	NR	Provided	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	Provided	NR
	• Hooters' Location	NR	Provided	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System :-			
	• Basements	NR	NR	NR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900LPM	900LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	NR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR


	• Location of Main Panel	NR	Provided	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	Provided	NR
	• Hooters' Location	NR	Provided	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System :-			
	• Basements	NR	NR	NR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	900LPM	900LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	NR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs	MR

N/16


15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	NR	NR	
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2015/WZ/787 Dated 18/05/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


26.4.18

Signature of the Inspecting Officer
Name : A.K. Jaiswal
Designation : A.D.O. (JWP)


27/5/18

Signature of the Inspecting Officer
Name : D.P. Bhardwaj
Designation : Dy.C.F.O. (West)