

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/ 1035

Dated: 11/05/18

FIRE SAFETY CERTIFICATE

Certified that M/s J. M. Convent School running on ground plus one upper floor of the building comprised of ground plus two upper floors only located at Puri Gali, Maujpur,, Delhi-110053, owned/occupied by J. M. Convent School was inspected by the officer concerned of this department on 27/04/2018 in the presence of Mr. Sukhbir Singh, Manager of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ...11/05/18... for a period of three years, subject to conditions, printed overleaf.

Issued on.....11/05/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

To,  
The Manager,  
M/s J. M. Convent School,  
Puri Gali, Maujpur,  
Delhi-110053,

Copy:-  
The Dy. Director of Education  
B-Block, Yamuna Vihar,  
Delhi-110053

o/c  
ly

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe eVacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : J. M. Convent School,  
Puri Gali, Maujpur, Delhi-110053
2. Building is comprised of : Ground plus two upper floors  
(School is running on ground plus one upper floor)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
7. Date of Inspection : 27/04/2018
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer  
from the building side : Mr. Sukhbir singh, Manager
10. Year of Construction : 1992
11. Applicant's letter No : J.M.C.S/DFS/4/14, Dated- 05/04/2018

| Sr. No. | Minimum Standards on fire prevention and fire safety U/R33  | Circular Requirement            | Provided at Site                | Remarks MR/NMR                  |
|---------|---|---------------------------------|---------------------------------|---------------------------------|
| 01      | Access to building  |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | 06 mtr.<br>N/A<br>N/A           | 06 mtr.<br>N/A<br>N/A           | MR<br>N/A<br>N/A                |
| 02      | Number, Width, Type and Arrangement of Exits  |                                 |                                 |                                 |
|         | a. Number of Staircases   |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>   | 01 nos.<br>N/A                  | 02 nos.<br>N/A                  | MR<br>N/A                       |
|         | B. Width of Staircases  |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>   | 1.50 mtr.<br>N/A                | 1.20 mtr & 0.90 mtr<br>N/A      | MR<br>N/A                       |
|         | c. Protection of exits  |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>   | N/A<br>N/A                      | N/A<br>N/A                      | N/A<br>N/A                      |
|         | d. No. of continuous staircases to terrace  | 01 nos.                         | 01 nos.                         | MR                              |
|         | e. Width of Corridor  | 1.50 mtr.                       | 1.50 mtr.                       | MR                              |
|         | f. Door Size  | 01 mtr.                         | 01 mtr.                         | MR                              |
| 03      | Compartmentation.   |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul> | N/A<br>N/A<br>N/A<br>N/A<br>N/A | N/A<br>N/A<br>N/A<br>N/A<br>N/A | N/A<br>N/A<br>N/A<br>N/A<br>N/A |
| 04      | Smoke Management System.  |                                 |                                 |                                 |
|         | <ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>   | N/A<br>N/A                      | N/A<br>N/A                      | N/A<br>N/A                      |




N/S

|    |  |     |     |     |
|----|--|-----|-----|-----|
| 14 | Captive Water Storage for Fire Fighting.                                 | N/A | N/A | N/A |
|    | • Underground tank capacity  | N/A | N/A | N/A |
|    | ➤ Draw-off connection  | N/A | N/A | N/A |
|    | ➤ Fire service inlet   | N/A | N/A | N/A |
|    | ➤ Access to tank   | N/A | N/A | N/A |
|    | • Overhead Tank capacity   | N/A | N/A | N/A |
| 15 | Exit Signage.  | N/A | N/A | N/A |
| 16 | Provision of Lifts.  |     |     |     |
|    | • Pressurization of Lift Shaft   | N/A | N/A | N/A |
|    | • Pressurization of Lift lobby   | N/A | N/A | N/A |
|    | • Communication in lift car  | N/A | N/A | N/A |
|    | • Firemen's grounding switch   | N/A | N/A | N/A |
|    | • Lift Signage   | N/A | N/A | N/A |
| 17 | Standby power supply   | N/A | N/A | N/A |
| 18 | Refuge Area.   |     |     |     |
|    | • Total area   | N/A | N/A | N/A |
|    | • Location   | N/A | N/A | N/A |
| 19 | Fire Control Room  |     |     |     |
|    | • Detector system panel  | N/A | N/A | N/A |
|    | • Flow switch panel  | N/A | N/A | N/A |
|    | • PA system panel  | N/A | N/A | N/A |
|    | • Battery backup   | N/A | N/A | N/A |
|    | • Building Floor Plans   | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.


Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate.

  
11/5/18

Signature of the Inspecting Officer  
Name :- Vijay Bahadur  
Designation :- A.D.O (TP)

ICF No 2  
01/5/11/15

DO(ED) submitted for approval plan.

  
DI (F) ND 2

  
11/5/18