

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2018/WZ/1440/992

Dated: 10/5/2018

FIRE SAFETY CERTIFICATE

Certified that M/S Shivam Foods, B- 79, G.T. Karnal Road, Industrial Area, New Delhi 110033 Located on Ground and First Floor in the building comprised of B, G + 2 upper floors owned / occupied by M/S Shivam Foods was granted NOC by this department vide letter no F6/DFS/MS/EH/2014/WZ/1440 dated 24/11/2014. The premise was re-inspected by the officers concerned of this department on 29/ 04 / 2018 in presence of Sh. Karan Sahgal and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Assembly Building Div- D-5** occupancy for ground & first floor only with effect from 10 / 5 / 2018 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 10/5/18 at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Civil Zone, 16, Rajpur Road, Delhi 110054 for information
2. The authorized signatory, M/S Shivam Foods, B- 79, G.T. Karnal Road, Industrial Area, New Delhi 110033

INSPECTION REPORT

1. Name & address of the building : M/S Shivam Foods , B- 79, GTK Road, Ind. Area, Delhi
2. Type of Occupancy : Restaurant (Restaurant running on G + First floor with 135)
3. Type of Case : Renewal (B + G + 2 upper floors storied building)
4. Details of previous NOC : F6/DFS/MS/EH/2014/WZ/1440 dated 24/11/2014
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 29/04/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Karan Sahgal
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated 09/04/2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mtr	6 mtr	M/R
		Directly Accessible	Directly Accessible	M/R
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	01 main staircase	Provided	Travel Distance meets the requirements with single staircase
		01 emergency staircase	Provided	M/R
	b. Width of staircases	1.5 mtr	1) 1.6 cm (2) 1.50 cm	M/R
		1.5 mtr	B/M closed	—
	c. Protection of exits	Required	Provided	M/R
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1	160 CM	M/R
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	Two exits	Provided	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fan provided	M/R
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10	16	M/R
	<ul style="list-style-type: none"> • Types 	ISI marked	04 ABC, 06 WCO ₂ & 06CO ₂	M/R
	<ul style="list-style-type: none"> • IS marking 		Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	Provided	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Smoke	M/R
	<ul style="list-style-type: none"> • Location of Main Panel 	GF	Provided	M/R
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public Address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Upper Floor 	Required	Provided	M/R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	04"	01	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	01	01	M/R
	<ul style="list-style-type: none"> • Hose Box 	01	01	M/R

12	Yard Hydrants.			
	• Total number of hydrants	01	Provided	M/R
	• Hose Box	01	Provided	M/R
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	180 LPM	Provided	M/R
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M/R
	➤ Head of the pump	40 m	Provided	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr	Provided	M/R
15	Exit Signage.	Required	Provided	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided (GF)	M/R
	• Flow Switch Panel			
	• PA System Panel	Required	Provided	M/R
	• Battery backup	Required	Provided	M/R
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/EH/2014/WZ/1440 dated 24/11/2014** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

M/3/5

Signature of the Inspecting Officer

Name: Rajesh Kumar

Designation: Asstt. Divisional Officer

Dy. Asst. WZ

8/15/18