

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No. F6/DFS/MS/Club/2018/NDZ/ 1654

Dated: 16/7/18

FIRE SAFETY CERTIFICATE

Certified that the **East End Club FC-13, CBD Ground, Karkardooma Court Road, Delhi-32**, owned/occupied by East End Club, comprised of basement ground plus two upper floors was granted fire safety certificate vide letter no. **F6/DFS/MS/Club/2015/NDZ/1132** dated **01/07/15**. The premises was re-inspected by the officer concerned of this department on **27/06/18** in the presence of **Sh. Rajesh Mittal (Manager)** and found that the Assembly building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules 2010 and found that the building is fit for occupancy Group D-6 "(Eating House)" with effect from **16/7/18** for a period of **three** years, subject to conditions printed overleaf.

Issued on **16/7/18** at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,
The Manager,
East End Club FC-13, CBD Ground,
Karkardooma Court Road, Delhi - 32.

Copy to:-
The Assistant Commissioner(Excise),
Office of The Commissioner Excise,Entt. & Luxury Tax,
L-Block Vikas I.P.Estate, New Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : East End Club FC-13, CBD Ground, Karkardooma Court Road, Delhi-32.
2. Building is comprised of : B+ G+ Two upper floors
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/Club/2015/NDZ/1132 dated-01/07/2015
6. Fire Safety direction letter No : Old requirements
7. Date of Inspection : 27/06/18
8. Name of the Inspecting Officers : ADO R.K.Yadav
9. Name of the designation of Officer from the building side : Sh. Rajesh Mittal
10. Year of Construction : 2002
11. Applicant's letter No : NIL dt. 11/06/2018

S.No	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Directive	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	45 m	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02 no.	02 no.	MR
	Basement	02 no.	02 no.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	1.8 m & 1 m	MR
	Basement	1.5 m	1.7m & 0.85m	MR
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	NA	NA	NA
	h. Door Size	2 m	2 m	MR
3	Compartmentation.			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	Basement	Ventilated	Ventilated	MR
	Upper floor	NA	NA	NA
5.	Fire Extinguisher			
	Total numbers	08 nos.	08 nos.	MR
	types	ABC & Co2	ABC & Co2	MR
	ISI marking	ISI marked	ISI marked	MR

W/H

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 nos.	01 nos.	MR
	Length of hose reel	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	NA	NA	NA
	Location of main panel	NA	NA	NA
	Location of repeater panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	Upper floor	NA	NA	NA
	sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	01 no.	01 no.	MR
	Hose box each floor	01 no.	01 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

10/17

14	Captive Water Storage for Fire Fighting.				
	Underground tank capacity	15,000 Ltrs.	15,000 Ltrs.	MR	
	Draw-off connection	NA	NA	MR	
	Fire service inlet	NA	NA	MR	
	Access to tank	NA	NA	MR	
	Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR	
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	Pressurization of Lift Shaft	NA	NA	NA	
	Pressurization of Lift lobby	NA	NA	NA	
	Communication in lift car	NA	NA	NA	
	Firemen's grounding switch	NA	NA	NA	
	Lift Signage	NA	NA	NA	
17	Standby power supply		NA	Yes	MR
18	Refuge Area.				
	Total area	N/A	N/A	N/A	
	Location	N/A	N/A	N/A	
19	Fire Control Room				
	Detector system panel	N/A	N/A	N/A	
	Flow switch panel	N/A	N/A	N/A	
	PA system panel	N/A	N/A	N/A	
	Batter backup	N/A	N/A	N/A	
	Building Floor Plans	N/A	N/A	N/A	

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/DFS/MS/Club/2015/NDZ/1132 dated 01/07/15 renewal under the under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer
Name:- R. K. Yadav
Designation:- ADO (LN)

DO (ED)
6/7

DY LPO/NDZ

633/CPD/NDZ
16-7-18

M.Scell FT/101
11/7