

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO.F6/DFS/MS/School/2018/SZ/ 1639

Dated: 13/7/18

**FIRE SAFETY CERTIFICATE**

Certified that the Pinnacle International School, located at D-Block, Shyam Vihar Phase-II, Najafgarh New Delhi-110043, comprised of ground plus one upper floor owned/occupied by Pinnacle International School, have complied with fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education GNCT of Delhi and verified by the concerned of this department on 05.07.2018 in presence of Sh. Sita Ram (Manager) & Sh. Arun Gaur (Principle) and that the building is fit for occupancy class B "Educational building" with effect from...13/7/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on .....13/7/18..... at New Delhi by

W  
13/7.  
97C Vipin Kental  
Chief Fire Officer  
SM

Copy to:-

1. The Director (Education), GNCT of Delhi, Old Secretariat Delhi 110054.
2. Manager, Pinnacle International School, D-Block, Shyam Vihar Phase-II, Najafgarh New Delhi-110043.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

# INSPECTION REPORT

1	Name & address of the building	Pinnacle international School D Block, Shyam Vihar Phase-II, Najafgarh New Delhi-110043		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New <b>(Ground plus one upper floor)</b>		
4	Details of previous NOC	Nil		
5	Fire safety directives letter No	Director of Education Cir.No.letter dated 1.03.2011 & UBBL-2016		
6	Date of inspection	5.07.2018		
7	Name of the inspecting Officers	S.P. Bhardwaj ADO Dwarka		
8	Name and designation of officers from the building side	Sh. Sita Ram (Manager) & Arun Gaur (Prinicpal)		
9	Year of construction	2018		
10	Applicant's letter No.	Nil dated 29.05.2018	<b>Ground plus one upper floor</b>	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. letter dated 01.03.2011/ UBBL-2016	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			MR
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	Two	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	MR
	e. Width of corridor	1.50 Mtrs.	3 Mtrs.	MR
	f. Door size	1.20 Mtr.	1.20 Mtrs.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			M/R
	basement	N/A		
			Natural ventilation	M/R

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	1 ABC for every 300 Sq. Mtrs. ISI	5 Nos.	MR
	Types		CO2 & ABC	MR
	ISI marking		Provided	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	One each floor	N/A
	Length of Hose reel hose	N/A	Provided	N/A
	Nozzle Diameter	N/A	Provided	N/A
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	450 LPM	N/A
	b. head of the pump	N/A	40 M	N/A
	c. Power supply	N/A	Provided	N/A
	d. Auto starting of pump	N/A	Provided	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	4000 Ltrs	N/A
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M/R

N/15

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any; CO2 Fire extinguisher provided near electric Panel</b>	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. dated 1.3.2011/UBBL 2016, grant of fire safety certificate is recommended.  
 Note:- Original letter dated 29.5.2018 from RWA for 9.1 Mtr. wide road is submitted by the management of School.  
 Accordingly DFA is put up for your approval and signature please.

*Sey* 5/7/18  
 S.P. Bhardwaj  
 ADO (Dwarka)

~~DO/20~~

*Chy*  
 6/2/18

7/3/20/20  
 6/7/2018

DCFO (S2)



1621/CF S2  
 12/2

*Chy*  
 9/7

CFD 5/7

m/s cell

FTM  
 10/7?

FT is put up for signat plan.

*Sey*