

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2018/SZ/ 1591

Dated: 9/7/18

FIRE SAFETY CERTIFICATE

Certified that the Bholi Ram Public School, E-57 to 69, Indira Park, Najafgarh, New Delhi- 110043, having Old block and New block, Old block comprised of ground floor plus one upper floor and New block is comprised of ground plus two upper floor, school running at ground plus one upper floor only, was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2015SZ/730 dated 012.05.2015. The said school building was re-inspected by the officer concerned of this department on 29.06.2018 in presence of Sh. Pardeep Kumar (Principal) and found that management has constructed 2nd floor at old block & interconnected both blocks at all floors, but school is running at ground & 1st floor & have deemed complied with the fire prevention and fire safety requirements in accordance with Circular dated 1.3.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from... 9/7/18 for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on 9/7/18 at New Delhi by

Vipin Kental
Chief Fire Officer
9/7/18

Copy to:-

1. The Director (Education), GNCT of Delhi, old Secretariat, New Delhi-110054.
2. The principle Bholi Ram Public School E-57-69, Indra Park Najafgarh New Delhi-110043.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Bholi Ram Public School, E-57 to 69 , Indira Park, Najafgarh, New Delhi-110043	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	Renewal (G+1)	
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/730 dated 12.05.2015	
5	Fire safety directives letter No	Directorate of Education Circular. F.16/Estate/CC/FireSafety/2011/3298 dated 01.03.2011	
6	Date of inspection	29.06.2018	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Pardeep Kumar (Principal)	
9	Year of construction	Old Block (Before 2008) and New Block (2015)	
10	Applicant's letter No.	BRPS/121/18 dated 14.06.2018	Both blocks are interconnected at all floors (Management has constructed 2nd floor at old block) But School running at ground & 1st floor.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 1.3.2011/ letter dated 12.5.2015	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	(Old Blk.) 02 No's (New Blk.) 01 No.	(Old Blk.) 02 No.'s (New Blk.) 01 No.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	(Old Blk.) 1.50 cms. 1.31 cms.&(New Blk.) 1.54 cms.	(Old Blk.) 1.50 cms &1.31 cms and (New Blk.) 154 cms	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Two	Two	MR
	e. Width of corridor	1.50 Mtrs.	150 to154 cms	MR
	f. Door size	1 Mtr.	90 to119 Cms.	MR being old case

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A

5	Fire Extinguishers			
	total numbers	1 CO2 OR ABC for every 300 Sq. Mtrs. ISI	16 Nos	MR
	Types		CO2 & ABC	MR
	ISI marking		Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank, capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	M/R

4/11

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any; ABC fire extinguisher for electric panel			M/R

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement as per under the rules DOE Cir. Dated 1.3.2011, renewal of Fire Safety Certificate vide letter no. F6/DFS/MS/School/2015/SZ/730 dated 12.05.2015 is recommended. Accordingly DFA is put up for your approval and signature please.

S.P. Bhardwaj
21/7/18
S.P. Bhardwaj
ADO (Dwarka)

Del. SW

[Signature]
21/7/18

DCFO (S2)

706/DOK/21/7/18

[Signature]
21/7



*1585/CF/SZ
21/7/18/19/7*

CFD SP M-SCell

FT is put up for signature please.

CF/SZ

S.P. Bhardwaj
21/7/18