

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2018/SZ/ 1581

Dated: 06/07/18

FIRE SAFETY CERTIFICATE

Certified that the **Sat Saheb Public School**, 101, C-Block, Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059, comprised of ground floor plus two upper floors having total 24 rooms, 10 rooms on ground floor, 10 rooms on first floor & 04 rooms on second floor, owned/occupied by Sat Saheb Public School was issued NOC by this department vide letter no. F.6/DFS/MS/2006/18 dated 03.01.2007. The School building was re-inspected by the officer concerned of this department on 22.06.2018 in the presence of Sh. Vijay Dabas (Admin.) and found that few rooms added on second floor and third floor has been constructed for personal purpose (as per undertaking). Sat Saheb Public School, have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises (**Ground floor 10 rooms, First floor 10 rooms & second floor 04 rooms only**) is fit for occupancy class "Educational" for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....06/07/18..... at New Delhi.


(VIPIN KENTAL)
CHIEF FIRE OFFICER


3/2/18

Copy to:-

1. The Manager,
Sat Saheb Public School, 101, C-Block,
Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School building is comprised of ground plus two upper floors in a four storied building.

INSPECTION REPORT

1. Name & address of the building : Sat Saheb Public School, 101, C-Block, Som Bazar, Nanhey Park, Uttam Nagar, New Delhi-110059.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/2006/18 dated 03.01.2007
5. Fire Safety directives letter No : N/A
6. Date of inspection : 22.06.2018
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Vijay Dabas (Admin.)
9. Year of Construction : Before 2006
10. Applicant's letter No. : S/S/P/S dated 23.04.2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per NOC dt. 03.01.2007	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 4.5 mtrs N/A	4.5 mtrs Directly accessible from road N/A	M/R, being old case M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No.'s N/A	02 No.'s N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	150 cms N/A	150 cms each N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Provided	MR
		150 cms.	150/100 cms	MR, being old case
	e. Width of Corridor			
	f. Door Size	100 cms	90/100 cms	MR, being old case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	10 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 no. 30 mtrs 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	Provided	MR
		30 mtrs	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

19.	Fire Control Room	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F.6/DFS/MS/2006/18 dated 03.01.2007 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- As per the undertaking given by the Manager (placed at C-49) school management will be using the old portion of the school building which is mentioned in Previous fire NOC letter no. F.6/DFS/MS/2006/18 dated 03.01.2007 (i.e. 10 rooms on GF, 10 rooms on FF & 04 rooms on SF) total 24 rooms. The new portion of building which is constructed after that is not in used for school purpose.



Sandeep
27/6/18

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

565/DOLSW
26/6/2018

Divisional Officer (South West)

[Signature]
26/6/18

DGO (S2)

[Signature]
27/6

CFO S2

M. scell

F.T.M.

[Signature]
28/6

F-T

letter is put up for Sign please

[Signature]
31/6/18

CFO (S2)

M. scell

[Signature]
4/7