

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2018 / W2 / 1559

Dated: 4 / 7 / 2018

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Aakarsh International( Nail Polish) I-94, Sector-3, Bawana Industrial Area, Bawana, Delhi-110039** located at **Ground floor only** in a building comprised of **Basement, ground ,first floor& second floor** owned/occupied by **M/s Aakarsh International** was been issued Fire Safety Certificate by this department vide this office letter no. **F.6/DFS/MS/2015/WZ/251 dated 24.02.2015**. The premise was re-inspected by the officer concerned of this department on **26.06.2018** in the presence of **Sh. Manoj Jain** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **“Class Industrial Building(G-2) Class ”for Ground floor only** with effect from .....4.7.18..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on .....4.7.18..... at New Delhi

  
(Atul Garg)

Chief Fire Officer  
Ph:-011-23414250

Copy to : -

1. M/s Aakarsh International, I-94, Sector-3, Bawana Industrial Area, Bawana, Delhi-39.

**INSPECTION REPORT**

1. Name & address of the building : M/s Aakarsh International, I-94, Sector-3, Bawana Industrial Area, Bawana, Delhi-110039.
2. Type of Occupancy : Industrial - Basemen t + G+FF & second floor- (Ground floor for cosmetic Basement, first & second floor closed)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2015/WZ/251 dated : 24.02.2015
5. Fire Safety directives letter No : NBC
6. Date of inspection : 26/06/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Manoj Jain
9. Year of Construction : 2012-13
10. Applicant's letter No. : Dairy No. 7001 Dated- 07.06.2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	01	NA
	• Basements	NA	01	NA
	b. Width of staircases			
	• Upper Floors	NA	1.20m	NA
	• Basements	NA	1.20m	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00m x2	Provided	MR

*h*

3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	09nos	10nos	MR
	• Types	ABC/CO2	ABC-8,Co2-02	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01 Required	Provided	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor(ground floor)	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA

11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA	NA	
		NA	NA	NA	
		NA	NA	NA	
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA	
		NA	NA	NA	
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	NA	NA	NA	
		NA	NA	NA	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		450 lpm	450 lpm	MR	
		40mtr	40mtr	MR	
		N/A	NA	N/A	
		N/A	NA	N/A	
		14	<b>Captive Water Storage for fire fighting.</b>		
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			NA	NA	NA
	NA		NA	NA	
	NA		NA	NA	
	NA		NA	NA	
	10000 ltr		10,000ltrs	MR	
Required	Provided		MR		
15	<b>Exit Signage.</b>	Required	Provided	MR	
16	<b>Provision of Lifts.</b>				

h

	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	Provided	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working conditions.

Keeping in view of the satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. 251 dated 24.02.2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Rajesh Kumar*

Signature of the Inspecting Officer  
Name :- Rajesh Kumar

Designation:- ADO/RN

*Dy Cfo/w2*

*Cfo West*

*29/06/18*

*FI PK*

*ADO/RN*

*As approved, f.t. letter is put up for your signature BS*

*1/11/18  
3/2*