

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018/ W2/1550

Dated 3/7/18

FIRE SAFETY CERTIFICATE

Certified that the **Bee Gee Motors** located at **Sector-B, DSIIDC Complex, Narela, Delhi-110040** comprised of **Single Story Building** owned/ occupied by **Bee Gee Motors** was issued NOC by this department for storage of petroleum Class "A" & "B" vide this office letter no. FS/3(A)DFS/BP/2004/WZ/323 dated 23.06.2004(Petrol Pump) & FS/C340/DF3/2010/CNG/211 Dated 12.07.2010(CNG filling station) and the Filling Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **15.06.2018** in the presence of **Mrs. Beena P. Desai, Proprietor** and that the building/ premises is **fit for storage of Petroleum Class A & B & Group-J** with effect from 3/7/18 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 3/7/18..... at New Delhi by


(Atul Garg)

Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. M/s Bee Gee Motors, Sector-B, DSIIDC Complex, Narela, Delhi--110040.

at

INSPECTION REPORT

1. Name & address of the building :Bee Gee Motors (Petrol Pump & CNG dispensing station) , Sector-B, DSIIDC Complex, Narela,Delhi-110040.
2. Type of Occupancy : Petroleum Filling station **Group 'J' (Ground floor only)**
3. Type of Case :Renewal
4. Details of previous NOC :F5/(3A)/DFS/BP/2004/323 Dated: 23.06.2004
FS/C340/DF3/2010/CNG/211 Dated 12.07.2010
5. Fire Safety directives letter No :NBC Part IV
6. Date of inspection :15/06/2018
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers
from the building side : Mr. Sukhbir Sharma
9. Year of Construction :
10. Applicant's letter No. : Nil dated 25.04.2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	08m	18m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA

R

M/3

	f. Door Size	1.0m	1.0m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	12nos	15nos	MR
	• Types	ABC & Co2	1 trolley 75 kg. , 10-ABC, 05 Co2- 10 kg	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

NY

11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		14	Captive Water Storage for fire fighting.	
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
	NA		NA	NA
NA	NA	NA		
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A


↓

2/5


	<ul style="list-style-type: none"> Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Fire buckets filled with sand, No smoking boards were found displayed in Hindi & English. No lose electric wiring were seen in premises & Co2 flooding system found provided		NA
				NA


The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate issued vide this department letter of even no. 323 dated 23.06.2004 & 211 dated 12.07.2010 under rule 35 of the Delhi Fire Service Rules 2010.



 Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN


 25/6/18

Dy. CFO/W2
 CFO West

 20/06/18

As approved, F.T. letter is being
 for your signature P1

 ADO/RN

CFO/W2

 16/7/18


 2/3