

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2018/ 1806

Dated: ~~28/6/18~~

FIRE SAFETY CERTIFICATE

Certified that the M/s Caffe Tonino located at H-9, H- Block, Mezzanine floor, Plaza Cinema Building, Connaught Place, New Delhi comprised of Ground + Mezzanine + 02 Upper floor, Restaurant running at Mezzanine floor only owned /occupied by M/s Caffe Tonino (A Unit of Pyramids), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 20-06-2018 in the presence of Mr. Jaideep (Manager) and found that the building / premises, is fit for occupancy class Assembly Building Group-D of Sub-Division D-5, Restaurant at Mezzanine floor only with effect from 28/6/18 -for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/6/18 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Officer

Copy to:-

1. The Chief Medical Officer (Lic-II),
NDMC, Palika Kendra, New Delhi - 110001.
2. The Manager,
M/s Caffe Tonino at H-9, H- Block, Mezzanine floor, Plaza Cinema Building,
Connaught Place, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. The means of escape shall be kept unobstructed / unlocked & remain available to the occupants for uninterested evacuation in case of an emergency.

N/A

INSPECTION REPORT

1. Name & address of the building M/s Caffe Tonino at H-9, H- Block, Mezzanine floor, Plaza Cinema Building, Connaught Place, New Delhi
2. Type of occupancy:- Assembly Building Group-D
Gr. + Mezzanine + 02 Upper floors, Restaurant is running at Mezzanine floor only
3. Type of case:- New Case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/06/18
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer from the building side:- Sh. Jaideep (Manager)
9. Year of construction:- Old Heritage
10. Applicant's letter No:- D-961/CMO-II/SI-I dated 16/05/2018

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	30 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80, 1.25 mtr.	1.80, 1.09 & 0.90 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr.	02 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	09 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR

M

M/7

6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Gr. Floor	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Office main lobby	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Mezz. Floor	Provided	MR
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm	150 mm	MR
	2) Number of hydrants per floor	02	02	MR
	3) Hose box	02	02	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR

13.	Pumping Arrangement	F/F System exiting with Plaza Cinema		
	1) Ground level			
	a) Discharge of main pump	2800 LPM	2800 LPM	MR
	b) Head of main pump	89 mtr.	89 mtr.	MR
	c) Number of main pump	01	01	MR
	d) Jockey pump out put	280 LPM	280 LPM	MR
	e) Jockey pump head	89 mtr.	89 mtr.	MR
	f) Stand by pump output	2800 LPM	2800 LPM	MR
	g) Stand by pump head	89 mtr.	89 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	2800 LPM	2800 LPM	MR
	b) Head of pump	89 mtr.	89 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank	10,000 ltr.	50,000 ltr.	MR

Handwritten mark

	capacity			
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

M.K. Sharma
25/6/18

Name :- M.K. Sharma
Designation :- ADO (CC)

Dy. CFO/NDZ

[Signature]

CFO - M.Scell FT/101
21/6.

24/06/18
27/6/18
As approved, R.T letter is put up for signatures
phase
CFO (NDZ)
M.Scell 21/6
25/6/18