

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2018 / W2 / 1536

Dated: 3 / 7 / 2018

**FIRE SAFETY CERTIFICATE**

Certified that the M/s G R D Cosmetics Industries located at M-46, Sector-2, Bawana Industrial Area, Bawana, Delhi-110039 comprised of Basement, ground & first floor only owned/occupied by M/s GRD Cosmetics Industries was been issued Fire Safety Certificate by this department vide this office letter no. F.6/DFS/MS/2015/WZ/151 dated 03.02.2015. The premise was re-inspected by the officer concerned of this department on 12.06.2018 in the presence of Sh. Harpreet Singh and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under "Class Industrial Building(G-2) Class " with effect from 3/7/18..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 3/7/18..... at New Delhi

(Attn Garg)

Chief Fire Officer  
Ph:-011-23414250

Copy to : -

1. M/s GRD Cosmetics Industries, M-46, Sector-2, Bawana Industrial Area, Bawana, Delhi-39.

**INSPECTION REPORT**

1. Name & address of the building : Ms GRD Cosmetics Industries, M-46, Sector-2, Bawana Industrial Area,  
Bawana, Delhi-110039.
2. Type of Occupancy : Industrial ( Basemen t + Ground & first floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/87/2015/WZ/151 dated : 03.02.2015
5. Fire Safety directives letter No :
6. Date of inspection : 12/06/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Sh. Harpreet Singh
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated- 09.05.2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	06m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	01	01	NA
	b. Width of staircases			
	• Upper Floors	1.25m	1.25m	MR(old case)
	• Basements	1.25m	1.25m	MR(old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	01	01	MR	
e. Width of Corridor	1520m	1.50m	MR	
f. Door Size	1.00m	1.10m	MR	
3	<b>Compartmentation.</b>			

*Handwritten signature*

	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	08nos	10nos	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO2	ABC-8,Co2-02	MR
	<ul style="list-style-type: none"> <li>• ISI marking</li> </ul>	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01 Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor(ground floor)</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			

	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 lpm	900 lpm	MR
		40mtr	40mtr	MR
		N/A	NA	N/A
		N/A	NA	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10000 ltr	10,000ltrs	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A

Y B

	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working conditions. The observations/ shortcomings issued and communicated vide this department letter of even no. 780 dated 23.02.2018 have been compiled by the management.

Keeping in view of the satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. 151 dated 03.02.2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

*Dy. Insp. / RN*  
*25/6/18*

*CRS weekly*  
*28/06/18*  
*PTDS*

*As approved, f.t. letter is being*  
*for your signature 01*

*CRS/w2*  
*27/7/18*

*27/7/18*