

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2018/SZ/ 1569

Dated: 05/07/18

**FIRE SAFETY CERTIFICATE**

Certified that the Gyan Vijay Model School, WZ-184, Palam, New Delhi, comprised of ground floor (10 Class Rooms) was issued fire safety certificate by this department vide letter No.F6/DFS/MS/School/2014/SZ/1182 dated 12.9.2014 . The said school building was re-inspected by the officer concerned of this department on 24.6.2018 in presence of Sh. Davinder Sehrawat (Manager) and found that the management has constructed one more upper floor and have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Cir. No. 3298-3398 dated 01.3.2011 and that the premises/building is fit for occupancy of class B "Educational Building" with effect from .....05/07/18... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on .....05/07/18..... at New Delhi by

W  
4/7  
(Vipin Kental)  
Chief Fire Service  
o/c  
Suj

Copy to:-

- 1 The Director (Education) Govt. of NCT of Delhi, Old Secretariat, New Delhi-110045.
2. The Principal, Gyan Vijay Model School, WZ-184, Palam, New Delhi.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	Gyan Vijay Model School, WZ-184A, Palam Village, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal/ Addition of Floor	Ground	Now G+1
4	Details of previous NOC	No.F6/MS/DFS/2004/SZ/1182 dated 12.9.2014		
5	Fire safety directives letter No	UBBL/ D O E Circular. 3298 dated 1.3.2011		
6	Date of inspection	24.6.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Davinder Sehwat (Manager)		
9	Year of construction	2012 & 2017		
10	Applicant's letter No.	Nil Dated 5.6.2018	(Ground plus one upper floor)	
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>UBBL/DOE CIR. Dated 1.3.2011</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Accessible from 6 Mtrs. road	MR being old case
	2) Gate width	4.5 Mtrs.	Direct Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	One	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.68 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtrs. & 1.20 Mtrs.	1 Mtrs. & 1.20 Mtrs.	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	Two at each floor	5 Nos.	MR
	Types			



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto. starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	<b>Exit Signage.</b>	N/A	N/A	N/A
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A



17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher provided near electric meter	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view compliance of the minimum standards on fire prevention and fire safety requirements as per DOE CIR. Dated 1.3.2011, grant of Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval and signature please.

*Sanyal*  
25/6/18  
S.P. Bhardwaj  
ADO (Dwarka)

~~DOSW~~

*[Signature]*  
26/6/18

747/DOSW  
26/06/2018

DCFO(S2)

*[Signature]*  
22/6



cfo sz

M/s cell FT/M.  
28/6

FT is put up for signature/plan.

1573/cfs2  
4/2

cfs2

M/s cell  
4/7

*Sanyal*  
21/7/18