

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/1444

Dated: 20/06/18

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Sarvodaya Kanya Vidyalaya, at Pkt B, Mayur Vihar-1, Delhi-91, comprised of ground plus one floor, owned/occupied by Rajkiya Sarvodaya Kanya Vidyalaya was issued FSC vide letter no. F6/DFS/MS/School/2011/2867 dated 28/11/14. The school building has complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 06/06/18 in the presence of Smt. Gomati Devi (Vice-Principal) of the school and found that the building is fit for occupancy class B 'Educational Building' for with effect from 20/06/18 for a period of **three** years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 201C, subject to conditions printed overleaf.

Issued on..... 20/06/2018 at New Delhi by

(Vipin Kental)
Chief Fire Officer

To,

The Vice-Principal,
Rajkiya Sarvodaya Kanya Vidyalaya,
Pkt B, Mayur Vihar-1, Delhi-91.

Copy to:-

- 1 The Dy. Director of Education,
D-Block, Anand Vihar, Delhi.
2. The Principal,
Rajkiya Sarvodaya Bal Vidyalaya,
Pkt B, Mayur Vihar-1, Delhi-91

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

ADD LN

1. Name & address of the building : RSKV at Pkt B, Mayur Vihar-1, Delhi-91.
2. Building is comprised of : A Block Ground & B Block G+1 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alteration
5. Details of Previous FSC : F.6/DFS/MS/School/2014/NDZ/14985 Dated-28/11/14
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398dt 01.03.2011
7. Date of Inspection : 06/06/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of
Officer from the building side : Smt.Gomati Devi (Vice-Principal)
10. Year of Construction : 1995 & 2016
11. Applicant's letter No : Dated 11/05/18

N O	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 m	06 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor (B block)	2 nos.	2 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1 no.	1 no.	MR
	e. Width of Corridor	1.5 M	1.5 M	MR
	f. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	20 Nos.	20 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

11/19

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The school building was issued shortcomings vide letter no. F6/DFS/MS/School/2017/2857 dated 03/11/17 which is rectified. The same were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2014/NDZ/1485 dated 28/11/14 (for ground floor only) renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended Fire Safety Certificate

R. K. Yadav
5/6/2018

Signature of the Inspecting Officer
Name:- R. K. Yadav
Designation:- ADO (LN)

DO (ED)

[Handwritten signature]
2/6

604/CF/NDZ
18/6/2018

604/CF/NDZ

[Handwritten signature]

FTA.

CFQ-

M.Scell.

[Handwritten signature]
15/6

Dr, FT letter is put up for signature plz
[Handwritten signature]