

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2018/SZ 1406

Dated: 15/06/18

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary School, Mahavir Enclave-II New Delhi-110045 having two blocks, comprised of ground plus one upper floor & (one block single storey is not in use) was granted NOC by this department vide letter no. F6/DFS/MS/School/2014/SZ/230 dated 13.02.2014. The said School building was re-inspected by the officers concerned of this department on 31.05.2018 in presence of Sh. Raj Kumar (Principle) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular no. 3298 to 3398 dated 01.03.2011 and that the building is fit for occupancy class B "Educational building" with effect from....14/06/18. for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on14/06/18..... at New Delhi by

14/6.
Vipin Kental
07c Chief Fire Officer
Sw

Copy to:-

1. The Director, (Education), SDMC, 23rd floor, Civic Centre, Minto Road, New Delhi.
2. The Principal S.D.M.C Pry. Boys School Mahavir Enclave-II, New Delhi
3. The Principal S.D. M.C. Pry Girls School, Mahavir Enclave-I, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	SDMC Primary School, Mahavir Enclave-II, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+1)		
4	Details of previous NOC	F/6/DFS/MS/School/2014/SZ/230 dated 13.02.2014		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	31.05.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Raj Kumar (Principle)		
9	Year of construction	2001 & 2009		
10	Applicant's letter No.	ME/II/P/S/NO./19 Dated 18.5.2018	Two blocks having ground plus one upper floor (One block having ground floor only not in use)	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement DOE. Cir. No. dated 1.3.2011.	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	3 Nos.	3 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.	02 No.1.5 Mtrs. In block 1 & 01 No. of 1.5 Mtrs. In block 2	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	1.50 Mtrs.	2.0 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	One CO2 of 2.5 kg or ABC for every 300 Sq Mtrs. ISI Marked	12 Nos.	MR
	Types		CO2, ABC	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N/7

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher Near Electric Panel	MR		


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of minimum standards on fire prevention and fire safety requirements as per DOE Cir. dated 1.3.2011, renewal of fire Certificate issued vide letter no.F6/DFS/MS/School/2014/SZ/230 dated 13.02.2014 is recommended.


Accordingly DFA is put up for approval and signature please.


 S.P. Bhardwaj
 ADO Dwarka

~~DO (SW)~~


4/6/18


~~DCFO (SZ)~~


S/C

634/20/180
4/6/2018

CF 3/4


Miscell


FTB

7/6/18


FT is for signature please.



1500/CF/SZ
14-6



Miscell 
14/6


11/6/18