

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/VG/2018/WZ/ 1556

Dated: 09/07/2018

FIRE SAFETY CERTIFICATE

Certified that the PVR Ltd. (Formerly Versus Video Game Parlour) located at S.F. – 10, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi was issued FSC vide Letter No. F6/DFS/MS/VG/2015/WZ/642, dated 22-05-2015. The premises was re inspected by the officers concerned of this department on 30-05-2018 in the presence of Mr. Devender Jha (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 04/07/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/07/18 at New Delhi by.


(Atul Garg)

Chief Fire Officer,
Delhi Fire Service

Copy to:

1. PVR Ltd. (Formerly Versus Video Game Parlour), S.F. – 10, 2nd Floor, Pacific Mall, Tagore Garden, New Delhi
2. Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi – 1100149.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Versus Video Game Parlour located at S.F. –
10, 2nd Floor, Paccific Mall, Tagore Garden, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Mall already issued NOC)
4. Details of previous NOC: No. F6/DFS/MS/VG/2015/WZ/642, dated 22-05-2015
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 30-05-2018
7. Name of the Inspecting Officer : Udai vir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Devender Jha (Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil dated 02-05-2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	1x137cm, 1x197cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 Exit	1m & 3m Provided	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	30 a/c per hr	NA	NA
	• Upper floors	12 a/c per hr	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	06 nos. each type	10 Provided	MR
	• Types	DCP & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	Not Applicable	Not Applicable	Not Applicable
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants: Common with the mall			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements: Common with the mall			
	• Ground Level	NA	Common with the mall	NA
	• Discharge of main pump	NA	Common with the mall	NA
	➤ Head of main pump	NA	Common with the mall	NA
	➤ Number of main pumps	NA	Common with the mall	NA
	➤ Jockey pump out put	NA	Common with the mall	NA
	➤ Jockey pump head	NA	Common with the mall	NA
	➤ Standby Pump out put	NA	Common with the mall	NA
	➤ Standby Pump Head	NA	Common with the mall	NA
	➤ Auto Staring/Manual stopping	NA	Common with the mall	NA
	➤ Pump House Access	NA	Common with the mall	NA
	• Terrace level	900 lpm	Common with the mall	MR
	➤ Discharge of pump	40 m	Common with the mall	MR
	➤ Head of the pump	Required	Common with the mall	MR
	➤ Power supply	Required	Common with the mall	MR
	➤ Auto starting of pump	Required	Common with the mall	MR
14.	Captive water Storage for fire fighting: Common with the mall			

14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 lr	30, 000 Litres	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/VG/2015/WZ/642, dated 22-05-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Udaivir Singh
26/6/18
Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Udaivir Singh
Designation ADO/WP

Name
Designation

DO/W
Udaivir Singh
26/6/18
Udaivir Singh
27/6/18
ADO/WP
28/06/18

ASK them to come through Adh'CP/LK
Udaivir Singh
28/06/18