

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2018/NDZ/ 1484

Dated: 25/06/18

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary Co-Ed School running at ground plus one upper floor of the building at B-Block, Pandav Nagar, Delhi-92, owned/occupied by EDMC Primary Co-Ed School Comprised of ground plus two upper floors was granted FSC vide letter F6/DFS/MS/School/2014/NDZ/1324 dated-22/10/14 (for G+1). The school building was inspected by the officer concerned of this department on 01/06/18 in the presence of Mrs. Madhu Bala Gupta (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/11 and found that the building (GF+FF) is fit for occupancy class B "Educational Building" with effect from 25/06/18 for a period of **three** years, subject to conditions printed overleaf.

Issued on 25/06/18 at New Delhi by

W
21/4
(Vipin Kental)
Chief Fire Officer

9/06/18

Copy to:-

- 1 The Principal,
EDMC Primary Co-Ed School,
B-Block, Pandav Nagar, Delhi-92.
2. The Director of Education,
EDMC Plot no.419,Udyog Sadan,
Patpargang Industrial Area,Delhi-92.

Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/12

1. Name & address of the building : EDMC Primary Co-Ed School, B-Block, Pandav Nagar, Delhi-92.
2. Building is comprised of : G+2 (School running at G+1, 2nd floor having 2 store room)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/School/2014/NDZ/1324 dated-22/10/14
6. Fire Safety direction letter No : F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/11
7. Date of Inspection : 01/06/18
8. Name of the Inspecting Officers: : ADO R.K. Yadav
9. Name of the designation of Officer from the building side : Mrs. Madhu Bala Gupta (Principal)
10. Year of Construction : 1995
11. Applicant's letter No. : Nil dated 12/03/18

S. No	Minimum Standards on fire safety requirements as per	Requirement	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 no.	2 no.	MR
	• Basement	N.A	N.A	N.A
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.5 m each	MR
	• Basement	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1 m	1 m	MR
3.	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	04 no.	Provided	MR
	Types	CO ₂ & ABC	Provided	MR
	ISI marking	ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A	N.A	N.A
	Length of hose reel hose	N.A	N.A	N.A
	Nozzle diameter	N.A	N.A	N.A
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A
8	MOEFA	N.A	Provided	MR
9	Public address System.	N.A	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	N.A	N.A	N.A
	➤ Head of the Pump	N.A	N.A	N.A
	➤ Power supply	N.A	N.A	N.A
	➤ Auto Starting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	N.A	N.A	N.A

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2014/NDZ/1324 dated-22/10/14 renewal under the circular no. F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/11 is recommended to grant Fire Safety Certificate.

R. K. Yadav
8/6/18

Signature of the Inspecting Officer
Name :- R. K. Yadav
Designation :- ADO (LN)

submitted for approval ph.

~~DO(ED)~~

DYCFD/NDZ,

[Signature]
9/6/18

[Signature]
11/6

FTM

CFD

M.Scell

[Signature]
13/6

San FT letter is put up for signature please

601/CFD/NDZ
13-6/22-6