

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2018/WZ/ 1553

Dated- 4 /07/2018

FIRE SAFETY CERTIFICATE

Certified that the **Laurel High The school** located at, **Behind IDPL CHBS Society Pitam Pura Village, Delhi – 110034**. Owned and occupied by **Millennium Child Education Society (Regd.) , 129 Harsh Vihar, Pitampura Delhi– 110034** comprised of **Ground + 03 Upper Floors** was issued FSC vide Letter No. **F6/DFS/MS/2015/WZ/537 Dated 16-04-2015**. The premises was re inspected by the officers concerned of this department on **19-06-2018** in the presence of **Sh. Mahajan (Chairman)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01-03-2011/NBC Part- IV and that the premises is fit for occupancy class "Educational" Group B with effect from 4/7/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on4.17.18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, Millennium Child Education Society (Regd.) 129 Harsh Vihar, Pitampura Delhi– 34.
2. Directorate Of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Laurel High, The School at pitam pura village, owned by Millennium child education Society (Regd.) 129 Harsh vihar, Pitampura Delhi 34.
2. Type of Occupancy : Educational (Ground + 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/WZ/537 Dated 16-04-2015
5. Fire Safety directives Letter No. : F6/DFS/MS/2004/2732 Dated 10-11-2004
6. Date of inspection : 19/06/2018
7. Name of the Inspecting Officer : udaivir singh, ADO (WP)
8. Name and designation of Officer from the building side : Sh. Mahajan (Chairman)
9. Year of Construction : 2007
10. Applicant's letter No. : nil Dated 02-06-2018

No. of Students= 829
No. of class rooms=28
Plot area=4044 m ²
Covered area.
G=663.9 M ²
1 st Floor=669M ²
2 nd Floor=325 M ²
3 rd Floor=159.99 M ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive issued/Cr.No.3298-3398 dated 1-3-11	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Provided >9m	MR
		Accessible	5m	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	2x150cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2 Provided	MR
	e. Width Of Corridor	1.5m	170cm Provided	MR
	f. Door Size	1m	1m (In cloud door frame)	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000Ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/WZ/537 Dated 16-04-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

ADO
19/6/18
Signature of the Inspecting Officer
Name Udaivir Singh
Designation ADO/WP

Signature of the Inspecting Officer
Name
Designation

DO/W Pl. check the address.

ADO/W
Mistake regretted the add. has been corrected.

DO/W
19/6/18

ADO
22/6