

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2018/WZ/1521

Dated: 29/06/2018

FIRE SAFETY CERTIFICATE

Certified that the Prakash Palace Banquet (A Unit of Prakash Continental Pvt Ltd) located at Ground and 1st Floor, 13, Printing Press Area, WazirPur Printing Press Complex, Delhi – 110035 in a building comprised of Basement + Ground Floor + 02 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/2014/WZ/1360 Dated 31-10-2014. The premises was re inspected by the officers concerned of this department on 08-06-2018 in the presence of Sh. Mohan Prakash Gupta (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D, Ground & 1st Floor only with effect from 29/6/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...29/6/18..... at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to: 1. The Dy Health Officer, North Delhi Municipal Corporation (Health Department, Civil Lines Zone), 16 Raj Pur Road, Delhi - 11005

2. Sh. Sh. Mohan Prakash Gupta, Prakash Palace Banquet (A Unit of Prakash Continental Pvt Ltd), 13, Printing Press Area, WazirPur Printing Press Complex, Delhi – 110035.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. **Basement shall not be used for any purpose.**
7. **The lift will run from Ground Floor to Upper Floors.**
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Prakash Palace Banquet (A Unit of Prakash Continental Pvt Ltd), 13, Printing Press Area, WazirPur Printing Press Complex, Delhi – 110035.
2. Type of Occupancy : Assembly (At Ground Floor + 1 upper floor) **In a building comprised of basement +G+2UFs**
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2014/1360 Dated 31-10-2014
5. Fire Safety directives Letter No. : Letter No. F6/DFS/MS/BP/96/370 dated 15-03-96
6. Date of inspection : 08-06-2018
7. Name of the Inspecting Officer : Udaivir singh ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Mohan Prakash Gupta (Owner)
9. Year of Construction : 1998
10. Applicant's letter No. : Nil Dated 10/05/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided, on main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	Old Case	1x127,1x152 & 1x90cm (Old case)	MR
	• Basements	NA	1x159,1x127 & 1x90cm	NA
	c. Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	1m (Old case)	MR

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	Provided	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR

13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	10000 litres	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		12,500 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts (Lift will run from Ground Floor to Upper Floors			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/2014/WZ/1360 Dated 31-10-2014 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Not; Earlier two terrace pumps of 900 lpm & 220l pm were seen but now one pump of 220 lpm was found removed. However the premises still meet the requirement.

~~Signature of the Inspecting Officer~~

~~Signature of the Inspecting Officer~~

Name Uday Vir Singh

Name

Designation AD/WP

Designation

~~Dd(W)~~ 13/6/18

~~Dy-PO (N2)~~ - EIC

~~CFO (N2)~~

Earlier building was only Pt G+1, Now it is G+2 Flr.

pls refer

14/06/18

~~Dd(W)~~

Since the guest house is running at second floor and already issued NOC/Not covered. 19/6/18

~~CFO (N2)~~

19/06/18

ft 11

~~DD/W~~

19/6/18