

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / W2 / 1535

Dated 3/17/18

FIRE SAFETY CERTIFICATE

Certified that the **Rohini Court Complex, District Court Rohini** located at **Sector-14, Rohini, Delhi-110085** comprised of **basement, ground and five upper floors** owned/ occupied by **District Court Rohini** was issued FSC vide this office letter no **F.6/DFS/MS/2012/897 dated 13/03/2012**. The premise was re- inspected by the officer concerned of this department on 14.06.2018 in the presence of **Sh. Raj Kumar/ A.E. (Elec.), & Sh. Subhash / J.E. (Elec.)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premise have therefore, deemed complied with the requirement under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy class Assembly with effect from ...3.17.18... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 3/17/18..... at New Delhi by

(Atul Garg)

Chief Fire Officer

Ph-011-23414250

Copy to:-

1. The Hon,ble District & Session Judge (NW), District Court Rohini, Sec-14, Rohini, Delhi.
2. The Executive Engineer (E),North West Electrical Div. , Public Works Department, Kashmere Gate, Opp. ISBT. , Delhi-110006.

INSPECTION REPORT

1. Name & address of the building : Rohini Court Complex, District Court Complex ,Sec-14, Rohini, Delhi.
2. Type of Occupancy :Business (B+G+03, 4 & 5 upper floors)
3. Type of Case :Renewal
4. Details of previous NOC :F.6/DFS/MS/2012/897 Dated: 13/03/2012
5. Fire Safety directives letter No :F.6/MS/DFS/BP/2000/1014 Dated: 12/06/2000
6. Date of inspection :14/06/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh Raj Kumar, AE(E), Sh. Subhash , JE/Elect
9. Year of Construction : 2007
10. Applicant's letter No. : No.23 (33)/NW Elec. Sub. Div./PWD/1178 Dated: 02/06/2018

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part 4	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	12m	MR
	• Gate width	05m	06m	MR
	• Width of internal road	6m	06m	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	08nos & 02 nos in Lawyer Chamber	08+02	MR
	• Basements	14nos	14nos	MR
	b. Width of staircases			
	• Upper Floors	1.5m each	4x1.85m, 2x1.53m, 2x1.45m, 2x1.50m	MR (old case)
	• Basements	1.5m each	2x1.53m, 12x1.45m, 2x1.50m (LC)	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	All	All	MR
e. Width of Corridor	1.50m	1.5m	MR	
f. Door Size	1.25m	1.25m	MR	
3	Compartmentation.			


	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided not functional	NMR
		12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	110nos	110 nos	MR
		ABC & Co2	ABC & Co2	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	(12 +2) nos	12+02 nos	MR
		30mm	Provided	NA
		05mm	Provided	NA
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR
		GF	Provided	MR
		Each floor	Provided	MR
		Required	Provided	MR
		At strategic location	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100mm	100mm	MR
		03	03	MR
		03	03	MR

12	Yard Hydrants.			
	• Total number of hydrants	18 nos	18 Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	2850LPM	2850lpm	MR
		70 M	70m	MR
		02	02	MR
		220 LPM	220lpm	MR
		70 M	70m	MR
		2850 lpm	2850 lpm	MR
		70m	70m	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2,50,000 ltrs	2,50,000 ltrs	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	30,000 ltr	30,000 ltrs	MR	
	Required	Provided	MR	
15	Exit Signage.			
Required	Provided	MR		
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
Required		Provided	MR	
17	Standby power supply			
Required	Provided	MR		


18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	NA	NA	NA
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. 54 dated 04.01.2018 have been compiled by the management.

Keeping in view the substantial compliance of the minimum standard on the fire prevention fire safety required under the rules, FSC issued vide letter no. F.6/DFS/MS/2012/897 dated 13/03/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


 Signature of the Inspecting Officer
 Name: - Rajesh Kumar
 Designation:- ADO/RN

Dy CPO/102



25/6/18


CPO West

20/06/18

FI PL

ADO/RN

As approved, F.I. letter is put up for your signature pl

CPO/102

21/6/18


21/6