

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2018/NDZI/ 1486

Dated: 25/6/18

FIRE SAFETY CERTIFICATE

Certified that the Shankar Public School, Main Road Mandawali Delhi-92, running a ground plus one upper floor of the building comprised of ground plus two upper floors owned/occupied by Shankar Public School was issued NOC vide letter No. F6/MS/DFS/2008/3033 dated 06/11/08. The school building was inspected by the officer concerned of this department on 08/05/18 in the presence of Mr. C.S.Kasana (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 Dated 17/01/2005 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground +1floor only with effect from 25/6/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....25/6/18.....at New Delhi by

W 21/6.
(Vipin Kental)
Chief Fire Officer

of 25/6/18

The Manager,
Shankar Public School,
Main Road Mandawali Delhi-92.

Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : ShankarPublic School at Main Road Mandawali
Delhi-92.
2. Building is comprised of : Ground plus two upper floor (school at G+1 floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/MS/DFS/2008/3033 dated 06/11/08
6. Fire Safety Circular No. : Circular No.262-362 Dated 17/01/2005
7. Date of Inspection : 08/05/18
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of
Officer from the building side : Mr. C.S. Kasana (Manager)
10. Year of Construction : 1994
11. Applicant's letter No : Dated 04/04/18

N O.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 Mtrs.	06 Mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.25 & 1.10M	1.25 & 1.10M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	1 No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 M	1.0 M	MR
	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	04 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

First-aid-Hose Reels.

Total numbers of each floor	1 no.	Provided	MR
• Length of hose reel hose	30 M	Provided	MR
• Nozzle diameter	5MM	Provided	MR

Automatic fire detection and alarming system.

• Type of detectors	N/A	N/A	N/A
• Location of main panel	N/A	N/A	N/A
• Location of repeater panel	N/A	N/A	N/A
• Alternate source of power	N/A	N/A	N/A
• Hooter's location	N/A	N/A	N/A

MOEFA

Public address System.

Automatic Sprinkler System.

Basement	N/A	N/A	N/A
• upper floor	N/A	N/A	N/A
• sprinkler above false ceiling	N/A	N/A	N/A
Internal Hydrants	N/A	N/A	N/A
• size of riser/down-comer	N/A	N/A	N/A
• Number of hydrants per floor	N/A	N/A	N/A
• Hose Box	N/A	N/A	N/A

Yard Hydrants.

• Total number of hydrants	N/A	N/A	N/A
• Hose Box	N/A	N/A	N/A

Pumping Arrangements.

Ground Level	N/A	N/A	N/A
➤ Discharge of main Pump	N/A	N/A	N/A
➤ Head of Main Pump	N/A	N/A	N/A
➤ Number of main pumps	N/A	N/A	N/A
➤ Jockey pump out put	N/A	N/A	N/A
➤ Jockey pump head	N/A	N/A	N/A
➤ Standby pump out put	N/A	N/A	N/A
➤ Standby pump Head	N/A	N/A	N/A
➤ Auto Starting /Manual stopping	N/A	N/A	N/A
➤ Pump House Access	N/A	N/A	N/A
• Terrace Level	N/A	N/A	N/A
➤ Discharge of pump	220 LPM	Provided	MR
➤ Head of the Pump	40 M	40 M	MR
➤ Power supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR

Captive Water Storage for Fire Fighting.

• Underground tank capacity	N/A	N/A	N/A
➤ Draw-off connection	N/A	N/A	N/A
➤ Fire service inlet	N/A	N/A	N/A
➤ Access to tank	N/A	N/A	N/A
• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	MR
• Signage.	N/A	N/A	N/A

115

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F6/MS/DFS/2008/3033 dated 06/11/08 renewal under the circular no.262-362 dated 17/01/2005 is recommended.

R. K. Yadav
24/9/2018

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO(LN)

DO(ED) *[Signature]*
25/5
DY (PO) MDG *[Signature]*

cfb (ND2) 1564
29/5/18

CFD. Pl mention width of staircase in performa.

Coastal/ND2
13-6/22-0

[Signature]
28/5

DO (E-) ? *[Signature]*
4/6