

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2018/SZ/ 1573

Dated: 28/6/18

FIRE SAFETY CERTIFICATE

Certified that **DAV Public School** located at Sector-B, Pocket-1, Vasant Kunj, New Delhi-110070, comprised of Basement, Ground plus two upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/696 dated 08/05/2015. The premises was re-inspected by officer concern of this department on 06/06/2018 in presence of Mr. Sanjay Sharma (Account Officer) and found that said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building/ premises is fit for occupancy class "Educational" Group-B as above with effect from 28/6/2018 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued on 28/6/18.... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Tel. 011-23412225

Copy to: -

1. The Principal, DAV Public School, Sector-B, Pocket-1, Vasant Kunj, New Delhi-110070
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	DAV Public School located at Sector-B Pkt-1, Vasant Kunj New Delhi-110070		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 2 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2015/SZ/696 Dated 08/05/2015		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	06.06.2018		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Sanjay Sharma, (Account Officer)		
10	Year of construction	1989		
11	Applicant letter No.	DAV/PS/VK/2018-19/28222 dated 07/05/2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 Mtr	12 Mtr.	MR
	• Gate width	5 Mtr	5 Mtr	MR
	• Width of internal road	NA	NA	NA
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basement floor	2 Nos	1 No + 1 Ramp	MR
	b. Width of Staircase			
	• Upper floors	1.50 m/0.75m	1.50 & 1.45 m	MR
	• Basement floor	1.50 m/0.75m	1.1m & Ramp 3 m	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	1 No	2 No	MR
	e. Width of corridor	1.5m	Provided	MR
	f. Door size	1 m	1 m	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	Required	Exhaust Fan provided	MR
	• Upper floors	NA	Open corridor	NA
5.	Fire Extinguishers.			
	• Total numbers	12 No's	40 No's	MR
	• Types	ABC/Co2	ABC-35, Co2-05	MR
	• ISI Marking	ISI Marked	Yes	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.		02 No's	MR
	• Length of hose-reel hose.	Hose-reel	30 mtr	NA
	• Nozzle Diameter		05 mm	NA

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	NA	NA	NA
	• Number of Hydrant per floor	NA	NA	NA
	• Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	• Total number of hydrants.	NA	NA	NA
	• Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	450 LPM	450 & 180 LPM	MR
	➤ Head of pump.	40 mtr	40 mtr (each)	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	NA	NA	NA
	• Draw-off connection.	NA	NA	NA
	• Fire Service Inlet.	NA	NA	NA
	• Access to tank.	NA	NA	NA
	• Overhead tank capacity.	10,000 Ltr	15,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provisions of Lifts.			
	• Pressurization of lift shaft.	NA	NA	NA
	• Pressurization of lift lobby.	NA	NA	NA
	• Communication in lift car.	NA	NA	NA
	• Fireman's switch.	NA	NA	NA
	• Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA

N/10

19.	Fire Control Room.			
	• Detector System Panel.	NA	NA	NA
	• Flow Switch Panel.	NA	NA	NA
	• PA system Panel.	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building floor plan	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.			NA
<p>The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2015/SZ/696 dated 08.05.2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
				<p style="text-align: right;"><i>Mehmood</i> 19/6/18</p> <p>Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>

DO (SD)

Anilam
20/6/18

Dr. C. B. (S2)

Kang
21/6

CFO (S1)

M. Scell

F.T.M.

U
22/6

A. R. T. letter put up for signature please

Mehmood
22/6/18 (ADO/SJ)

CFO (S2) *M. Scell* *U*
29/6



1532e/CFO/SZ
27-6