

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001



No.F6/DFS/MS/School/2018/NDZ/ 1328

Dated: 06/06/18

FIRE SAFETY CERTIFICATE

Certified that the D.A.V. Public School Mausam Vihar, Delhi-51, owned/occupied by D.A.V. Public School, Comprised of ground plus two upper floors was granted FSC vide letter no. F6/DFS/MS/School/2015/NDZ/281 dated-27/02/15. The school building was inspected by the officer concerned of this department on 16/04/18 in the presence of Mrs. Vandana Kapoor (Principal) of the school and found that the school has constructed porta cabin on 3rd floor for office purpose only and have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service rules 2010 and found that the ground plus two floors of building is fit for occupancy class B "Educational Building" with effect from 06/06/18 for a period of **three** years, subject to conditions printed overleaf.

Issued on 06/06/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service


Copy to:-

1. The Principal,
D.A.V. Public School Mausam Vihar, Delhi-51.
2. The Joint Director of Education(Land & Estate)
Directorate of Education, Lucknow Road, Delhi-54.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : D.A.V. Public School Mausam Vihar, Delhi-51.
2. Building is comprised of : Ground +3 (3rd floor porta cabin)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F6/DFS/MS/School/2011/488 dated-15/03/11⁽ⁿ⁺²⁾
6. Fire Safety direction letter No : DFS Act 2007 & Rules 2010
7. Date of Inspection : 16/04/18
8. Name of the Inspecting Officers: : ADO R.K. Yadav
9. Name of the designation of Officer
from the building side : Mrs. Vandana Kapoor (Principal)
10. Year of Construction : 2009
11. Applicant's letter No. : SRSDAV/PS/2017-18 dated 10/02/18

S. N	Minimum Standards on fire safety requirements as per	Requirement	Provided at Site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	15 m	MR
	Gate width	4.5 M	4.5 M	MR
	Width of internal road	N.A	N.A	N.A
2.	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	3 no.	3 no.	MR
	• Basement	N.A	N.A	N.A
	b. Width of Staircases			
	• Upper Floor	1.5 m	1.6 m, 1.55 & 1.5M	MR
	• Basement			
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
	e. Width of Corridor			
	f. Door Size	1.5 m	1.5 m	MR
		1 m	1 m	MR
3.	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4.	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	35 nos.	Provided	MR
	Types	CO ₂ & ABC	Provided	MR
	ISI marking	ISI marked	Provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	03 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A
8	MOEFA	N.A	Provided	MR
9	Public address System.	N.A	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	3 no	3 no	MR
	Hose Box	3 no	3 no	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	➤ Discharge of main Pump	N.A	N.A	N.A
	➤ Head of Main Pump	N.A	N.A	N.A
	➤ Number of main pumps	N.A	N.A	N.A
	➤ Jockey pump out put	N.A	N.A	N.A
	➤ Jockey pump head	N.A	N.A	N.A
	➤ Standby pump out put	N.A	N.A	N.A
	➤ Standby pump Head	N.A	N.A	N.A
	➤ Auto Starting /Manual stopping	N.A	N.A	N.A
	➤ Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	10,000 liters	20,000 litres	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.
 Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/DFS/MS/School/2015/NDZ/281 dated-27/02/15 (for G+2) renewal under the rule Delhi Fire Service rules 2010 is recommended.

R. K. Yadav
27/02/2018

Signature of the Inspecting Officer
 Name :- R. K. Yadav
 Designation :- ADO (LN)

DO(ED) *[Signature]*
115118

DY I/O/NDZ *[Signature]*

S13/NDZ
9/5/16-6

C.F.P. What's use of porta column on 3rd floor

NDZ

[Signature]
9/5

Say, as per the undertaking submitted by principal 3rd floor is being used as activity room for children. Submitted Please