

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / 1390

Dated: 14 / 08 / 2018



FIRE SAFETY CERTIFICATE

Certified that the **Delhi School of Professional Studies & Reserch, 9, Insitutional Area, Sector-25, Rohini, Delhi-110085** comprised of **Basement + Ground floor +03 upper floor** owned/occupied by the **Delhi School of Professional Studies & Reserch** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule, 2010 and verified by the officer concerned of fire service on 10.06.2018 in the presence of **Dr. Ravinder Vinayek** and that the building/ premise is fit for occupancy "**Group B Educational**" with effect from 14/8/18..... for a period of three years, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 14/8/18..... at New Delhi


(Atul Garg)
Chief Fire Officer
Ph:-011-23414250


Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Chairman, Delhi School of Professional Studies & Reserch, 9, Insitutional Area, Sector-25, Rohini, Delhi-110085.

INSPECTION REPORT

1. Name & address of the building : Delhi School of Professional Studies & Reserch, 9, Insitutional Area, Sector-25 Rohini, Delhi-110085. (Basement + Ground + 03 upper floors)
2. Type of Occupancy : Educational
3. Type of Case : Addl./ Alt. /Renewal
4. Details of previous NOC : F.6/DFS/MS/2012/4827 dated : 03.12.2012
5. Fire Safety directives letter No : F 6/DFS/MS/BP/2015/113 dated 15.04.2015.
6. Date of inspection : 10.06.2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Dr. Ravinder Vinayek
9. Year of Construction : 2004/2017
10. Applicant's letter No. : DSPSR/ADMIN/2018/I/10180 Dated 10.04.2018

Plot Area- 1999.50 m2

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/ NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m	MR
	• Gate width	6m	6m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	03	MR
	• Basements	03	03	MR
	b. Width of staircases			
	• Upper Floors	1.50 m each	1.50m x 2 & 1.20m	MR
	• Basements	1.50m each	1.50m x 2 & 1.20m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	01	02	MR	
e. Width of Corridor	NA	NA	NA	
f. Door Size	1m	1m	MR	
3	Compartmentation.			

M/21

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fan	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	28nos	30 nos	MR
	<ul style="list-style-type: none"> • Types 	ABC & Co2	30-ABC	MR
	<ul style="list-style-type: none"> • ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	100mm	NA
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NA	01	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	01	NA
12	Yard Hydrants.			

N/22

	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	01Nos	NA
		NA	01Nos	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		1620 lpm	1620 lpm	MR
		60 M	60 M	MR
		02	02	MR
		180 LPM	180 LPM	MR
		60 M	60 M	MR
		1620 lpm	1620 lpm	MR
		60 M	60 M	MR
		Required	Provided	MR
		900 lpm	900 lpm	MR
		30m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50000 ltr.	50000 ltr.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		15,000 ltr	20,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided DG Set	MR
18	Refuge Area.			


h

M/29

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The observations/ shortcomings issued and communicated vide this department letter of even no. 1244 dated 13.05.2016 have been compiled by the management.

Keeping in view of satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules and fire safety guidelines issued vide letter of even no. 113 dated 15.04.2015, it is recommended to issue Fire Safety Certificate under rule 2010.


 Signature of the Inspecting Officer
 Name :- Rajesh Kumar
 Designation:- ADO/RN

Dy cfo(w2 - on leave

~~CFO(w2)~~
12/06/16

f i p s

As approved, F.T. letter is prepared for your signature PI

~~ADO/RN~~

~~CFO(w2)~~
12/06/16

1 ACY
13/6