

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2018 /schme/1318

Dated: 05/06/2018

FIRE SAFETY CERTIFICATE

Certified that **Govt. Sarvodaya Co-ed Sr. Sec. Vidyalaya, Sec-7, Rohini, Delhi 110085** comprised of **(04 blocks) Three blocks Ground + One Upper Floor & One Block Ground Floor only** owned/occupied by **Govt. Sarvodaya Co-ed Sr. Sec. Vidyalaya**, was issued fire safety certificate vide letter no. **F6/DFS/MS/2014/WZ/School/1675 dated 30/12/2014**. The premises was re-inspected by the officer from this department on dated **15/05/2018** in the presence of **Sh. Ved Prakash (Vice -Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition and there is no additional construction. The premises have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy under **Educational building** with effect from **05/06/2018** for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/06/18 at New Delhi by

(Atul Garg)

Chief Fire Officer

Ph: 011-23414250

Copy to:

1. The Principal, Govt. Sarvodaya Co-ed Sr. Sec. Vidyalaya, Sec-7, Rohini, Delhi 110085
2. The Director of Education, Old Secretariat, Delhi.

INSPECTION REPORT**(04 Blocks) Three Blocks G + 1 & One block GF**

1. Name & address of the building : Govt. Sarvodaya Co-ed Sr. Sec. Vidyalaya, Sec-7, Rohini
2. Type of Occupancy : Education
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2014/WZ/School/1675 dated 30/12/2014
5. Fire Safety directives letter No : Director of Education
6. Date of inspection : 15/05/2018
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Sh. Ved Prakash (Vice -Principal)
9. Year of Construction : 1995, 1996 & 2004
10. Applicant's letter No. : FSC Renewal/18 dated 06/04/2018

PA- 15000 Sq. Mtr , CA- 5300 Sq. mtr ,

| S. No | Minimum Standards on fire prevention and fire safety U/R 33 | DOE Requirement | Provided at site | Remarks MR/NMR |
|-------|---|---|---|-------------------|
| 1 | Access to building | | | |
| | • Road width | 06 mtr | 06 mtr | M/R |
| | • Gate width | Directly Accessible | Directly Accessible | M/R |
| | • Width of internal road | N.A. | N.A. | N.A. |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 06 | 07 | M/R |
| | • Basements | N.A. | N.A. | N.A. |
| | b. Width of staircases | | | |
| | • Upper Floors | A Block 1.5 mtr B Block 1.5 mtr C Block 1.5 mtr | 1.70, 1.70 & 1.32 mtr 1.44 & 1.45 mtr 1.44 & 1.46 mtr | M/R M/R M/R |
| | • Basements | N.A. | N.A. | N.A. |
| | c. Protection of exits | | | |
| | • Fire check door | N.A. | N.A. | N.A. |
| | • Pressurization | N.A. | N.A. | N.A. |
| | d. No. of continuous staircases to terrace | N.A. | N.A. | N.A. |
| | e. Width of Corridor | 1 mtr | Provided double door of 1 mtr | M/R |
| | f. Door Size | | | |

| | | | | |
|----|---|-----------------|-----------------|------|
| 3 | Compartmentation. | | | |
| | <ul style="list-style-type: none"> • Fire check door | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Water Curtain | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Fire Dampers | N.A. | N.A. | N.A. |
| 4 | Smoke Management System. | | | |
| | <ul style="list-style-type: none"> • Basements | 30 a/c per hour | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Upper floors | 12 a/c per hour | N.A. | N.A. |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | 36 | 38 | M.R |
| | <ul style="list-style-type: none"> • Types | ISI marked | 20- ABC, 16 Co2 | M.R |
| | <ul style="list-style-type: none"> • IS marking | | Yes | M.R |
| 6 | First-Aid Hose Reels. | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor | 30 m 5 mm | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Length of hose reel hose | | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Nozzle diameter | | N.A. | N.A. |
| 7 | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> • Type of detectors | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Location of Main Panel | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Location of Repeater Panel | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Alternate source of power | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Hooters' Location | N.A. | N.A. | N.A. |
| 8 | MOEFA | N.A. | N.A. | N.A. |
| 9 | Public Address System. | N.A. | N.A. | N.A. |
| 10 | Automatic Sprinkler System. | | | |
| | <ul style="list-style-type: none"> • Basement | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Upper Floor | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Sprinkler above false ceiling | N.A. | N.A. | N.A. |

| | | | | |
|----|---|------|------|------|
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | N.A. | N.A. | N.A. |
| | • Number of hydrants per floor | N.A. | N.A. | N.A. |
| | • Hose Box | N.A. | N.A. | N.A. |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N.A. | N.A. | N.A. |
| | • Hose Box | N.A. | N.A. | N.A. |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N.A. | N.A. | N.A. |
| | ➤ Head of Main pump | N.A. | N.A. | N.A. |
| | ➤ Number of main pumps | N.A. | N.A. | N.A. |
| | ➤ Jockey Pump out put | N.A. | N.A. | N.A. |
| | ➤ Jockey pump head | N.A. | N.A. | N.A. |
| | ➤ Standby Pump out put | N.A. | N.A. | N.A. |
| | ➤ Standby Pump Head | N.A. | N.A. | N.A. |
| | ➤ Auto Starting/ Manual stopping | N.A. | N.A. | N.A. |
| | ➤ Pump House Access | | | |
| | • Terrace level | | | |
| | ➤ Discharge of pump | N.A. | N.A. | N.A. |
| | ➤ Head of the pump | N.A. | N.A. | N.A. |
| | ➤ Power Supply | N.A. | N.A. | N.A. |
| | ➤ Auto Starting of pump | N.A. | N.A. | N.A. |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | N.A. | N.A. | N.A. |
| | ➤ Draw-off connection | N.A. | N.A. | N.A. |
| | ➤ Fire service inlet | N.A. | N.A. | N.A. |
| | ➤ Access to tank | N.A. | N.A. | N.A. |
| | • Overhead Tank capacity | N.A. | N.A. | N.A. |
| 15 | Exit Signage. | | | |
| | | N.A. | N.A. | N.A. |

| | | | | |
|----|--|------|------|------|
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Pressurization of Lift lobby | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Communication In lift Car | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Fireman's Grounding Switch | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Lift Signage | N.A. | N.A. | N.A. |
| 17 | Standby power supply | N.A. | N.A. | N.A. |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N.A. | N.A. | N.A. |
| | ➤ Location | N.A. | N.A. | N.A. |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Flow Switch Panel | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • PA System Panel | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Batter backup | N.A. | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Building Floor Plans | N.A. | N.A. | N.A. |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N.A. | N.A. | N.A. |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F2/DFS/MS/2015/School/WZ/181 dated 09/02/2015** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

RK
18/5

Signature of the Inspecting Officer

Name : Rajesh Kumar

Designation: Asstt. Divisional Officer

Dy CPO
24/5/15
CPO
30/5/15
TID

As approved, F.T. letter is put up for your signature pl
1 Acc